Predominant Climate Exposure Strains - Thermal Degradation Testing Compared to Historical and Future Climate Scenarios

Petra Rther, Klodian Gradeci and Malin Sletnes

SINTEF Community. Department for architecture, building materials and constructions,
Hgskoleringen 7A, 7461 Trondheim, Norway, petra.ruther@sintef.no

Abstract. *The service life of a building or structure is often presumed to be 60 years. Products used in the building envelope are often covered by a facade material on the exterior side. Hence, the failure of these products is not easily observable, and the repair or replacement is normally not technically nor economically feasible. Thus, these products are expected to endure the entire estimated lifetime of the building. Service life prediction of these products is based on accelerated ageing tests, whose aim is to measure future possibilities of materials' durability under their expected service life. Preliminary calculations of acceleration factors are discussed and related to historical and future climate scenarios for a dataset from Calgary, Canada. The changes in temperature threshold values for this dataset is significant. Relating the measured values to a duration of a typical accelerated durability test indicates that the test duration is sufficient for a service life of 102 years according to historical climate, but only 52 years taking into account an assumed climate change.*

Keywords: *Durability Testing, Accelerated Ageing, Future Climate Scenarios, Exterior Applications.*

1 Introduction

The service life of buildings and building products is presumed to be 60 years. Wall membrane and roofing products, including adhesive products, are widely used in modern building assemblies and the service life of these products that play an important role in ensuring the air and rain tightness of the buildings has to reach 60 years. Furthermore, the inspection of these products, that are often hidden from visual inspection by cladding material mounted on the outermost layer of a building, is difficult.

Wall membrane and roofing products are usually subjected to an accelerated ageing procedure (see Table 1), depending on the use of the product in question. The test standards are designed with regards to the product in question and the prevailing climate condition in the use area of the product.

The ageing procedures are often, but not always a combination of what is believed to be a realistic climatic condition: elevated temperatures, (UV) radiation, water spray, freeze-thaw cycles, to mention the most common ones. Studies on material degradation usually involve a very detailed study of the degradation mechanism. The common ground for building products is usually their application area and not the type of material. Hence, test procedures should preferably account for the climatic strains, and attempt to reproduce the climatic conditions in service (Riahinezhad *et al.*, 2019) as correctly as possible.

While many test procedures are cycling several climatic agents, *e.g.* solar radiation and humidity, or humidity and elevated temperatures, this study will discuss implications for the testing in elevated temperatures, and discuss whether the effects of climate change, hence increased temperatures, need to be taken into account when designing accelerated ageing procedures.

2 Brief Review of Accelerated Weathering Methods

In order to be able to link the weather conditions to accelerated ageing methods, the temperatures are compared to the elevated temperatures of some European and international test standards for products used on the exterior of wall and roof assemblies.

Table 1. Summary of the most relevant ageing procedures for building envelope materials.

Standard	Temperature	RH	Test duration	Acceleration	Application
EN 1296:2000	70 �C	Not stated	24 weeks	not stated	Roofing membranes
EN 1297:2004	60 �C	10 � 5 % ¹	not stated	not stated	Roofing membranes ²
NT BUILD 495	63 � 5 �C	not stated	not stated	not stated	Materials and components used in the building envelope ³
NS 8140:1985	75 � 5 �C BPT	not stated	not stated	not stated	See footnote ⁴
ETAG 004	(1) 70 �C (2) 50 �C /- 20 �C	(1) 10-30% (2) 30%	(1) 80 cycles, 3h+1h spray and 2h rest (2) 7 h/16 h	not stated	External Thermal Insulation Composite Systems (Etics) with Rendering ⁵
EOTA TR 010: 2004	M ⁶ 60 � �C (BST) S ⁶ 70 � 3 �C	65 � 5% (drying conditions)	5000 hours	5000 h = 5 years ⁷	Liquid applied waterproofing kit
CAN/ULC – S741 (2008)	50�C		32 days	not stated	Air barrier materials ⁸

¹ The relative humidity shall be (10 5) % after 30 min of the dry period.

² In addition to heat and humidity the standard requires UV radiation and cyclic water spraying

³ The test method is based on cycling radiation, water spray, frost and laboratory climate.

⁴ The test method resembles the Nordtest NT Build 495 method with minor adjustments.

⁵ The systems must pass a series of tests regarding the performance of the rendering after the cycles

⁶ Distinguishes between M (moderate climate) and S (severe climate). Weathering cycles include water spray. Focus on radiation exposure.

⁷ The AF refers to the radiation exposure.

⁸ CAN/ULC-S741 conditioning includes UV exposure followed by extended heat exposure. UV exposure includes 210 hours (10 hr for 21 days) of UV radiation according to ASTM G154. Heat exposure includes placing the specimens in an air circulation oven for either 772 hours at 502C for non-accessible air barrier material or 336 hours at 502C for accessible air barrier materials.

Register for free at <https://www.scipedia.com> to download the version without the watermark

The above summary shows that most products for exterior applications in the building envelope are tested under elevated temperatures between 50C and 70C for between 32 days and 24 weeks. The acceleration factors stated are usually connected to the radiation exposure and not the thermal degradation.

3 Historical and Future Temperature Values

The selected location is Calgary, Canada. Two sets of climate data generated in Gaur *et al.* (2019) that include the following:

- 15 historical climate data set, and
- 15 climate data set for a climate change scenario in which the global climate temperature change is forecast to be 3.5C.

The reader is referred to Gaur *et al.* (2019) for more in-depth understanding of the methodology used, while a short description follows. A merged observational climate time-series (1986–2016) for the city of Calgary was prepared from the hourly observations (surface global horizontal irradiance, total cloud cover, rainfall, relative humidity, air temperature, station pressure, 10 m wind-speed and wind-direction), and daily observations of the snow-depth from the collection of all of the Environment and Climate Change Canada (ECCC) climate gauging stations located within the domains of Calgary and containing more than one year of data between the time-period: 1986–2016. The database of climatic projections from

CanRCM4 LE, Global Climate Model (GCM), was used to extract climatic projections for Calgary spanning the historical and future time-periods. In total, 15 members of the hourly CanESM2 LE projections covering the historical and the future time-periods were extracted for the grids covering the Calgary for the generation of 15 historical and 15 projected time-series of the climate variables.

Data was analysed to find the time periods where temperatures lie above a distinct temperature threshold. Temperature steps of 10°C between a range of -45°C and +45°C. Results are presented below for historical data and for the chosen climate scenario, together with averages, standard deviations and differences.

Figure 1. Number of days above temperature threshold for historical and future climate, temperatures above 0°C.

Register for free at <https://www.scipedia.com> to download the version without the watermark

The analysis of the climate data presented in Figure 1 shows a significant deferral of the average temperatures towards higher temperature levels. The number of days where the temperature exceeds 0°C increases for example by 1490 in the course of a 30-year period, or by an average of 50 days per year. For elevated temperatures the relative increase in days above the threshold value is significant: The accumulated period where the average temperature exceeds 30°C increased 3.52 times from 30 days to 352 days in a 30-year period. Correspondingly, the amount of time accumulated at lower temperatures decrease

4 Investigation of Acceleration Factors

In order to ensure that building materials exposed to outdoor conditions have the quality to endure the desired service life, accelerated laboratory testing is conducted. A brief review of some common test methods is presented in Table 1. The tests commonly include amongst others solar radiation and elevated temperatures between 50°C and 70°C, for some test methods the temperatures are cycled and/or alternated with water spray.

The service life of buildings and building parts that are not to be replaced is often set to between 50 and 60 years (Byggforsk, 2017), for materials and components in the building envelope that are accessible for replacement between 25 and 30 years.

Hence, the durability test should aim for testing a service life of 25-30 years or 50-60 years, respectively. The common dilemma with durability testing is to keep the test duration as short

as possible, *i.e.* to accelerate the test as much as possible, without generating degradation effects caused by elevated temperatures not present in a real application.

The following sections explore and discuss acceleration factors along with respective test durations for thermal degradation processes based on the above presented historical and future climate scenarios.

4.1 Methodology

Polymeric materials used in building materials are subject to degradation mainly caused by photoirradiation and thermal degradation. The dependence of the rate of thermal degradation on the temperature can be described by the Arrhenius law:

$$k = A \cdot e^{\left(\frac{-E_a}{RT}\right)} \quad (1)$$

where A is a pre-exponential factor, E_a [J/(mol K)] is the activation energy, $R = 8.314$ J/mol is the gas constant, and T [K] is the temperature. A temperature acceleration factor AF_{temp} may then be calculated as the ratio between the reaction rate in the accelerated weathering test k_1 and the natural outdoor weathering k_2 , leading to the following equation for the acceleration factor AF_{temp} :

$$AF_{temp} = \frac{k_1}{k_2} = e^{\left(\frac{E_a}{R} \left(\frac{1}{T_1} - \frac{1}{T_2}\right)\right)} \quad (2)$$

where T_1 and T_2 denote the temperature in the accelerated weathering test and the natural outdoor weathering, respectively. Given that the pre-exponential factor A is temperature independent, the calculation of the acceleration factor is only dependent on the value of the activation energy E_a and the two temperatures T_1 and T_2 (Meeker et al). The activation energy is strongly dependent on the material composition, the interaction between different chemical agents, the presence of catalysts, and hence very challenging to estimate for a complex material. However, for the purpose of this study four different activation energies have been used for the calculations: 72 kJ/(mol K) (as suggested by Riahiinezhad *et al.*, 2019), 90 kJ/(mol K), 60 kJ/(mol K) and 50 kJ/(mol K).

The following assumptions and approximations are taken in the investigation of the acceleration factor:

- The pre-exponential factor A in Equation 1 does not vary during the degradation process.
- The calculations are solely based on thermal degradation.
- The reaction mechanism, and hence the activation energy, does not vary during the degradation process.
- The chosen values for E_a are either chosen from literature (72 kJ/(mol K) from Riahiinezhad *et al.*, 2019) or parametrically assumed in order to explore the influence of the activation energy on the overall result.
- The temperature values for the outdoor exposure is based on average hourly values.

Acceleration factors are calculated based on Equation 2 for four different laboratory test temperatures $T_1 = 60^\circ\text{C}$, 70°C and 80°C and an effective outdoor temperature T_2 , where the lowest included temperature is 0°C , assuming that thermal degradation processes below 0°C might be neglected for the purpose of this study.

Figure 2. Acceleration factors plotted against average outdoor temperature for 80C (dashed line), 70C (solid line) and 60C (dotted line) laboratory test temperature for different activation energies.

The value of the acceleration factor AF depends (given the assumptions and approximations stated in section 4.1) solely on the activation energy E_a and the two temperatures T_1 and T_2 . Table 2 shows the acceleration factors calculated for an activation energy of 72 J/(mol K) for different temperatures T_1 and T_2 . Figure 2 shows acceleration factors AF for different values of E_a .

In the further course of the calculations the focus will be on an activation energy of $E_a = 72$ kJ/(mol K), as shown in Figure 3 with a more detailed plot. With all assumptions considered, the acceleration factor varies between 23 and 1325 for a test temperature of 80C, 11 and 648 for a test temperature of 70C and between 5 and 304 for a test temperature of 60C.

Basing the calculation of the test duration on annual average values leads to an acceleration factor of 379 for historic ($T_2 = 4,7C$) and 225 ($T_2 = 9,4C$) for future climate scenarios (for $E_a = 72$ kJ/(mol K) and 70C test temperature), leading again to a laboratory test duration of 28 days and 48 days.

Table 2. Acceleration factors AF for $E_a = 72$ J/(mol K).

$T_2 [�C]$	$T_1 [�C]$		
	60	70	80
0	304	648	1325
5	172	366	749
10	99	211	432
15	58	124	254
20	35	74	152
25	21	45	93
30	13	28	57
35	8	18	36
40	5	11	23

Figure 3. Acceleration factor plotted for $E_a = 72$ kJ/(mol K) for three different laboratory test temperatures for average outdoor temperatures between 0C and 40C.

5 Laboratory Test Duration

In order to estimate a laboratory test duration, an average temperature representing the outdoor temperature during the test period is to be calculated. The temperature data is divided into temperature ranges of 5C between 0C and 40C (assuming that the thermal degradation processes below 0C might be neglected). Further, the average temperature for each interval and the according duration is derived from the climate data. For the calculation of the acceleration factor for the respective temperature range, T_2 is set to the average temperature of the respective interval.

The results of the calculation are shown in Figure 5 for three different laboratory test temperatures. Up to now, the average outdoor temperature T_2 is set to the average outdoor temperature T_1 . The laboratory test duration (for a simulation of a 30-year outdoor test period) is 49 days based in historical climate scenarios and increased to 94 days based on future climate scenarios.

Figure 4. Laboratory test duration [days] for three different laboratory test temperatures T_1 based on historic and future climate scenarios.

With a calculation of the outdoor temperature T_2 in the above described way, the duration of the accelerated test is based on shorter time intervals with their respective duration based on hourly mean values. This contributes to a more accurate calculation, compared to e.g. using and average monthly or annual values, where the calculated test duration is considerably shorter (see section 4.1).

Due to the uncertainty in estimations of acceleration factors, test procedures for durability evaluation in product standards or for certification purposes normally specify longer test periods than those calculated from the Arrhenius equation. Thus, these tests have an inherent error margin to be on the safe side with regards to durability. This is known as stress testing, and the goal of the test is to assess whether it is probable that a product will have sufficient durability in the end use environment rather than specifying a particular service life. The error margin of durability testing may become smaller in the future due to climate change. For instance, in a common test method for roofing membranes (EN 1296, 2000), the temperature during the laboratory test is set to 70 °C. According to test duration of 24 weeks (168 days) assuming an activation energy of 72 kJ/(mol K) this test roughly corresponds to an outdoor exposure period of 102 years based on historical climate data. Based on the future climate scenario, however, the laboratory testing would only correspond to 53 years of outdoor exposure.

6 Conclusions

The results show a significant influence of the increasing temperature on the accumulated amount of time where certain temperature threshold values are exceeded. For the Calgary data, where the historic average temperature is 4.7°C and the future average temperature over a 30-year time period is 9.4°C, the increase in amount of days where the threshold value exceeds 30°C is from 30 to 352.

In a durability test, based on the calculated acceleration factors, given a number of assumptions, based on thermal degradation and on historic climate data for Calgary, 49 days account for an outdoor test period of 30 years. Based on future climate data, the test duration must be increased to 94 days.

Compared to a commonly used laboratory durability test for roofing membranes (EN 1296, 2000), the test duration of 24 weeks (168 days) accounts for an outdoor test period of 102 years for historical climate and 53 years for future climate.

This calculation shows that future climate scenarios should be considered when designing laboratory experiments.

7 Future Work

This work is based on temperature data measured at a meteorological station. In order to account for microclimate at the exact location where the material in question is applied, it would be interesting to study the differences for temperature values. Also, different geographical locations and their future climate scenarios need to be explored to take into account different climate zones. The further exploration of degradation processes in order to deepen the understanding of thermal degradation and possible interactions between thermal degradation and other climatic strains needs to be further explored.

Acknowledgements

This study was funded by the project ‘TightEN - Durable adhesive airtight solutions for energyefficient building envelopes’ (www.tighten.no), the aim of developing robust test, evaluation and prediction methodologies for ensuring durable adhesive airtight solutions for energy efficient building envelopes. Research Council of Norway; Country: Norway; Grant number: 294894.

ORCID

Petra Rther: <https://orcid.org/0000-0003-0245-6813>

Klodian Gradeci: <https://orcid.org/0000-0002-9837-3512>

Malin Sletnes: <https://orcid.org/0000-0001-8458-4653>

References

- ASTM E632-82(1996). Standard Practice for Developing Accelerated Tests to Aid Prediction of the Service Life of Building Components and Materials (Withdrawn 2005), ASTM International, West Conshohocken, PA, 1988, www.astm.org.
- Byggforsk 700.320 (2017). Intervaller for vedlikehold og utskifting av bygningsdeler (Intervals for maintenance and replacement of building parts), SINTEF Community, Trondheim, Norway (in Norwegian).
- CAN/ULC-S741 (2008). Standard for Air Barrier Materials – Specification.
- EN 1296 (2000). Flexible sheets for waterproofing - Bitumen, plastic and rubber sheets for roofing - Method of artificial ageing by long term exposure to elevated temperature. The European Standardization Organization.
- EN 1287 (2004). Flexible sheets for waterproofing - Bitumen, plastic and rubber sheets for roofing - Method of artificial ageing by long term exposure to the combination of UV radiation, elevated temperature and water. The European Standardization Organization.
- EOTA TR 010 (2004). Exposure procedure for artificial weathering. EOTA European Organisation for Technical Approvals.
- ETAG 004 (2013). External Thermal Insulation Composite Systems (Etics) with Rendering, EOTA. European Organisation for Technical Approvals.
- Gaur, A., Lacasse, M. and Armstrong, M. (2019). Climate Data to Undertake Hygrothermal and Whole Building Simulations Under Projected Climate Change Influences for 11 Canadian Cities. *Data*, 4(2), 72.
- Meeker, W.Q., Escobar, L.A. and Chan, V. (2002). Using accelerated tests to predict service life in highly variable environments. In Jonathan W. Martin and David R. Bauer, Editors, Service life Prediction. *Methodology and Metrologies*, 805 of ACS Symposium Series, 396-412. American Chemical Society, Oxford University Press.
- NS 8140:1985 (1985). Method of exposure of building components and building materials to accelerated climatic strains in a vertical position. The Norwegian Standardization Organization.
- NT BUILD 495 (2000). Building materials and components in the vertical position: Exposure to accelerated climatic strains, Nordtest.
- Riahinezhad, M., Eve, A., Armstrong, M., Collins, P. and Masson, J.F. (2019). Field temperature and moisture loads from a building envelope as the basis for accelerated aging of barrier membranes. *Canadian Journal of Civil Engineering*, 46, 969-978. <https://doi.org/10.1139/cjce-2018-0757>.

Register for free at <https://www.scipedia.com> to download the version without the watermark