Analysis of the Degradation Condition of Elementary Schools

Sónia Raposo

Buildings Department, Laboratório Nacional de Engenharia Civil, Av. do Brasil 101, 1700-066
Lisboa, Portugal, sraposo@lnec.pt

Abstract. *Currently, there is still no information regarding the performance of public buildings after their construction and the relationship with the needs for carrying out maintenance activities. This paper presents some of the main anomalies detected in six schools, built between 1997 and 2003 in Lisbon. The analysis of the degradation condition of these schools was based on data obtained through detailed visual inspections, carried out in three distinct periods of their operation phase, 2007, 2013 and 2018. The highest level of severity mainly concerns defects on buildings structure and buildings envelope and results from bad decisions made during design and/or construction. Therefore, there are serious problems related to the premature deterioration of these educational buildings, requiring expensive, complex and unplanned major repairs to achieve their specified design service life. This work highlights the need for greater involvement of school building management entities, in the early stages of the building process, including design, tendering, construction and handover.*

Keywords: *Elementary School, Building Condition, Anomalies, Durability.*

1 Introduction

The building condition assessment (BCA) is a systematic inspection, review, and report on the state of a building's structure, construction elements and systems. The BCA provides an identification of elements anomalies and the expected costs to remedy those deficiencies. This is an important step for the management of buildings maintenance and should be applied to the existing elementary public school portfolio of Lisbon. This network of schools includes more than 100 buildings with construction ages ranging from the nineteenth century to the beginning of this century (Raposo, 2011). Despite the existence of schools operating in very old buildings, are the most recent schools, built after 1980, that present major problems of conservation and maintenance (Raposo *et al.*, 2008).

In the present paper, the results obtained through visual inspection of six school establishments, built between 1997 and 2003, are presented. Inspections were carried out in 2007, 2013 and 2018 and it was possible to identify some recurring anomalies and causes for the accelerated and premature degradation that occurs in these buildings.

2 Research Methodology

In 2007 Raposo, Fonseca and Brito (2008) carried out a preliminary research on six elementary school of recent construction in Lisbon. The work was developed in two phases: (i) collection and treatment of information from the design phase and from the use and operation phase, (ii) fieldwork with detailed visual inspection of the buildings. In 2013 an inspection and BCA was performed of the building's structural and envelope components and playgrounds and outdoor spaces (Luís, 2013), and of the building's interior elements, including finishes, walls, ceilings, doors and plumbing (Nogueira, 2013). In 2018, the National Laboratory for Civil Engineering

carry out an assessment of the maintenance condition of 55 kindergarten (k) and elementary schools (EB1), for the Municipality of Lisbon (Vilhena *et al.* 2019). Extensive and detailed photographic and written records were made about anomalies detected allowing its comparison over time.

Table 1 shows the building characteristics of Prista Monteiro School (PM), Vale de Alcântara School (VA), Alto da Faia School (AF), Padre Rocha e Melo School (PRM), Alta de Lisboa School (AL) and Vasco da Gama School (VG) integrating the kindergarten and three levels of basic education.

Table 1. School Buildings Characteristics.

Schools	Year	Pupils	Level	GA (m2)	Floors	Year of Inspection
PM	1997	110	EB1	2200	2	2007-2018
VG	1999	600	k+EB1/2/3	8800	3	2007-2018
VA	2001	130	k+EB1	1700	2	2007-2018
AF	2001	340	k+EB1	4000	3	2007-2013-2018
PRM	2002	330	k+EB1	3000	2	2007-2018
AL	2003	330	k+EB1	3300	2	2007-2013-2018

3 Results

3.1 Foundation and Structure

The structure of VA School building is a system of slabs, columns and beams in reinforced concrete. The inspection carried out at this school in 2018, revealed the existence of serious anomalies in the structure namely, the existence of extensive structural deformations and the existence of wide opening cracks in multiple walls and ceilings on the two floors of the building.

Figure 1 shows the result obtained through inspections carried out in 2007 and 2018, where for inspection in 2007 were observed concrete deformations and water infiltration through exterior partition walls. They were identified foundations settlement problems and water infiltration through the roof in several classrooms (Vilhena *et al.*, 2019). Following this inspection, the school was closed for further rehabilitation intervention.

Figure 1. VA School: deterioration process of the exterior partition wall in 2007 (a) and 2018 (b). Cracks in walls in 2007 (c) and 2018 (d).

The 2018 survey, carried out in AF school, revealed the existence of anomalies in the outdoor constructive elements. The most frequent anomalies in these elements are oriented cracking,

severe fracture, differential settlements and deteriorated expansion joints without sealant. Some of these defects were detected since 2007, when only six years had passed on handover of the building. Figure 2 shows the result obtained through inspections carried out in 2007, 2013 and 2018, on the supporting wall located in AF school's outdoor spaces. It is possible to observe the existence of settlements and structural movements that remain unsolved.

Figure 2. AF School-outdoor spaces: deformation and settlement of the supporting wall and the recurring appearance of cracks. Anomaly evolution in 2007 (a), 2013 (b) and 2018 (c).

AL School was implanted on a landfill site, which is very steep along the longitudinal and transversal development of the building. The building structure is in reinforced concrete and is made of two blocks connected by an access ramp and stairs. In 2007, the existence of several anomalies resulting from the differential settlement of the two blocks was already visible (cracking in walls and broken elements). Although several repairs have been carried out in the building, 2013 and 2018 surveys revealed that the settlement movement remains active and the cracks in the walls and floors continue to appear (Fig. 3a). In AL, AF and PRM Schools, deteriorated expansion joints without filling material and sealant was observed (Fig. 3b,c,d,e). Lack of repair of the joints exposes the building elements to water infiltration and mechanical actions.

Register for free at <https://www.scipedia.com> to download the version without the watermark

Figure 3. AL School: foundation settlement movement: broken stone and construction joint opening in 2013 (a). Expansion joints without sealant: AF School in 2007 (b) and 2018 (c); PRM School in 2007 (d) and 2018 (e).

3.2 Building Envelope

3.2.1 Roofs

Three of the six buildings have flat roofs (PRM, AL and VA schools), AF school presents a mixture of flat and sloping roofs in metal sheet, PM school present a sloping roof covered with

ceramic tiles, and VG School presents a non-traditional roof covering made of ceramic pellets. In PM School, infiltrations water problems continue to be observed since 2007 survey, in the area of the gymnasium affecting both the ceiling and the floor. The AF School continues to present problems between the several flat and sloped roofs boundary buildings (Fig. 4a). Skylights are the element that most frequently presents anomalies caused by water infiltration. It was possible to observe the degradation mechanism in ceilings, walls and floor coatings, caused by water infiltration through skylights in PMR School (Fig. 4b,c).

Figure 4. AF School: mixture of flat and sloping roofs in metal sheet (a). Water infiltration problems between the building's roofs. PMR School skylights problems in 2018 (b), (c).

3.2.2 Exterior walls, windows and doors

Part of the exterior walls of AF School is made up of *Corten* steel panels and it was found that over the years, colour changed from orange-brown to dark brown as expected (the rust layer transforms into a patina layer) (Fig. 5a, 5b). However, aesthetically the overall wall covering did not result because there are panels with different colors, which may have been the result of localized repair work or replacement of some panels over the years. The wall facade presented serious problems of corrosion and lack of fixation, with risk for building users (Fig. 5c). In PRM School, the cladding of ventilated facades in wooden panels presented several anomalies such as corrosion of the panels, degradation of the paint, and uneven joint opening (with large local openings) without any filling (Fig. 5d,e) exposing the building elements to water infiltration.

Figure 5. AF School – exterior walls in *Corten* steel panels: colour change from 2007 (a) to 2018 (b). Corrosion and fixation problems in panels in 2018 (c). PRM School wooden panels degradation in 2007 (d) and in 2018 (e) with 16 years of service life.

In PRM School, damaged or missing door locks and handles were observed in the surveys. These failures severely reduces the adequate serviceability of the exterior doors (Fig. 6a,b).

These anomalies were detected in 2007 in doors with 5 years of service life. In general, some problems with rain penetration were observed in windows and non-operational interior polystyrene blinds is a very frequent anomaly. In AF School the outdoors shading were broken and deformed caused by its proximity to the playing field (Fig. 6c,d).

Figure 6. PRM School: missing door locks and handles 2007 (a) and 2018 (b). AF School: outdoors shading broken and deformed in 2007 (c) and 2018 (d).

3.3 Building Interior

3.3.1 Floors, walls, ceilings and doors

At PRM School, the degradation mechanism of the floor finishes, in the arts and crafts areas, next to the classrooms, caused by frequent water leakages from the washbasin siphons, has been observed since the 2007 inspection. In 2018, the placement of floor covering patches in this area was observed. Figure 7 (a,b,c) shows three stages of the vinyl floor covering degradation process caused by wet-dry cycles exposure conditions.

Figure 7. PRM School: vinyl floor degradation process caused by wet-dry cycles exposure conditions. Area in good condition and severely damaged area in 2007 (a,b); floor repaired in 2018 (c).

In the VA, AL, VG and PM Schools, cracks in interior to exterior walls and partitions walls were observed in 2018. In VA School, the severity and extent of the affected areas, indicates that the emergence of cracks is related to structural problems and differential settlements. In general, the most frequent anomalies in walls are related with deficient protection of corners and lack of adoption of wainscot/paneling elements in corridors and areas of intensive use.

Degradation in wall painting due to the use of adhesive tape for the exhibition of students' work was observed in the inspection carried out in 2007. In 2018 survey this anomaly was observed more frequently and over a larger area of walls (Fig. 8a).

In ceilings, moisture and water ingress are the most frequent anomalies. Figure 8 (b,c) shows the increased severity of this phenomenon in VA School, that may have resulted initially from lack or loss of waterproofing capacity of the building envelope (in 2007) and later resulted from the combination of several causes including building structural and foundations settlement problems (in 2018).

Figure 8. AF School: degradation in wall painting due to the use of adhesive tape for the exhibition of students' work in 2018 (a). VA School: water infiltrations in the ceilings in 2007 (b) and in 2018 (c).

The model of the sliding doors used to separate the classrooms from the arts and crafts areas and in bathrooms (PRM, PM and AF Schools) presented several functional problems related to unsuitable serviceability, vertical misalignment and deficient fixation tracks causing localized wear on the floors finishes (Fig. 9a). The use of large bellows doors to separate the gym from school cafeteria is a widely used solution in these recent buildings schools. This solution aims to open the spaces with an area for students to perform shows/theaters an area for the audience. Due to their characteristics, these doors are large (length and height) and are heavy, which makes manual maneuvering difficult. These doors are now permanently closed and are not used because they require maintenance and repair actions without which their safe use is not guaranteed (Fig. 9b). At PRM School, door closer need to be repaired in interior fire doors. In 2007, these elements were damaged (Fig. 9c), while in the 2018 survey it was found that the element was not placed where it was supposed to be (Fig. 9d).

Register for free at <https://www.scipedia.com> to download the version without the watermark

Figure 9. AF School: sliding door anomaly (a) non-operational bellows doors (b). PRM School: door closer anomaly in fire doors in 2007 (c) and 2018 (d).

3.3.2 Sanitary services

In 2018 survey, it was found that all schools continue to have recurrent problems and anomalies in the sanitary equipment and in the water supply and wastewater drainage networks. These installations are used intensively and not always in the most appropriate way. The most frequent

anomalies in these systems continue to be (i) the breakdown of the toilet flushes, (ii) fixing problems of water faucets and (iii) problems with the drainage capacity of the wastewater network. The lack of proper maintenance and misuse, results in nonfunctional equipment and sometimes in floods. Figure 10 (a) shows the poor fixing of the water tap and deficient drainage of the wastewater, (b) failure in the flushing system causing waste of water and (c) anomaly in the floor box of the wastewater network.

Figure 10. PRM School: anomalies on water tap and in the water flow, 2007 (a) failure in the flushing system, 2018 (b) and anomaly in the floor box covering finish of the wastewater network, 2018 (c).

4 Conclusions

This article presents the results of three inspections carried out in 2007, 2013 and 2018, on six school buildings built after 1997. The study revealed the existence of severe and unexpected degradation in these buildings. Anomalies related to the settlement of foundations and movements in the structure, are probable causes for the problems in other construction elements (cracking in interior and exterior walls and water infiltration). Observations made over the years showed that many of the structural problems are not stabilized what may have been caused by execution and/or design errors. It was found that one of the schools, with 19 years of service life, had to close, due to the existence of structural failures that endangered the health and safety of building users. Structural problems must be solved before carrying out many of the minor repairs, but they are complex, expensive, and so postponed.

Building schools should be designed to have a long service life, up from 50 years, so premature degradation of buildings is a problem with negative environmental, social and economic impacts. This work highlights the need for greater involvement of school building management entities, in the early stages of the building process, including design, tendering, construction and handover, to ensure that buildings and building elements fulfil their function for their specified design service lives.

ORCID

Sónia Raposo: <https://orcid.org/0000-0002-7683-1391>

References

- Luis, J. (2013). *Characterization of the degradation condition of the exterior building elements and outdoor spaces of school establishments in service* (in Portuguese). Master Thesis, Universidade Técnica de Lisboa – Instituto Superior Técnico, Lisboa, Portugal.

- Nogueira, W. (2013). *Characterization of the degradation condition of the interior building elements of school establishments in service* (in Portuguese). Master Thesis, Universidade Técnica de Lisboa – Instituto Superior Técnico, Lisboa, Portugal.
- Raposo, S., Fonseca, M. and Brito, J. (2008). Survey of the state of degradation of the school buildings of the Lisbon region. In *Proceedings of the XI International Conference on Durability of Building Materials and Components*, Istanbul, Turkey, 1789-1796.
- Raposo, S. (2011). *The management of maintenance activity in public buildings. Model and strategies for a sustainable intervention* (in Portuguese). PhD Thesis, Universidade Técnica de Lisboa - Instituto Superior Técnico, Lisboa, Portugal.
- S478-19 (2019). *Durability in buildings*. Ontario, Canada: Canadian Standards Association.
- Sousa, L., Ferreira, M., Mota de Sá, F., Oliveira, C., Raposo, S., Sigbjornsson, R., Rupakhety, R., Zonno, G., Meroni, F., Bianco, F. and D'Amico, S. (2012). Quantitative seismic risk evaluation and mapping: cases of schools and residential facilities in Lisbon and Algarve. In *Proceedings of the 15th World Conference on Earthquake Engineering*, Lisbon, Portugal, 8836-8845.
- Vilhena, A., Vasconcelos, A., Batista Coelho, A., Vicente, M. and Raposo, S. (2019). *Maintenance condition assessment of schools of the Municipality of Lisbon. Kindergarten and elementary schools* (in Portuguese). Scientific Report 259/2019 – Laboratório Nacional de Engenharia Civil. Lisboa, Portugal.

Register for free at <https://www.scipedia.com> to download the version without the watermark