


ENGINEERING CHANGE NOTICE

1. ECN **605030**

Page 1 of 2

Proj.
ECN

2. ECN Category (mark one) Supplemental <input type="checkbox"/> Direct Revision <input checked="" type="checkbox"/> Change ECN <input type="checkbox"/> Temporary <input type="checkbox"/> Standby <input type="checkbox"/> Supersedeure <input type="checkbox"/> Cancel/Void <input type="checkbox"/>	3. Originator's Name, Organization, MSIN, and Telephone No. G. W. Ryan, 8M100, A3-37, 376-5114	4. USQ Required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	5. Date 9/13/96
	6. Project Title/No./Work Order No. TWRS FSAR Development	7. Bldg./Sys./Fac. No. Tank Farms	8. Approval Designator N/A
	9. Document Numbers Changed by this ECN (includes sheet no. and rev.) WHC-SD-WM-CN-004, REV. 0	10. Related ECN No(s). N/A	11. Related PO No. N/A
12a. Modification Work <input type="checkbox"/> Yes (fill out Blk. 12b) <input checked="" type="checkbox"/> No (NA Blks. 12b, 12c, 12d)	12b. Work Package No. N/A	12c. Modification Work Complete N/A Design Authority/Cog. Engineer Signature & Date	12d. Restored to Original Condition (Temp. or Standby ECN only) N/A Design Authority/Cog. Engineer Signature & Date
13a. Description of Change Full replacement of Revision 0 with Revision 1 document. NOTE: ACCORDING TO SECTION WP-6.7, REV. 0 OF WHC-CM-6-32, <i>SAFETY ANALYSIS AND NUCLEAR ENGINEERING WORK PROCEDURES</i> , CALCULATION NOTES ARE USED TO DOCUMENT THE ORIGINATOR'S ANALYSIS BUT ARE NOT TO BE USED TO AUTHORIZE ACTIVITIES OR JUSTIFY FACILITY MODIFICATIONS, OR CHANGES TO AN AUTHORIZATION BASIS, SAFETY BASIS, OR DESIGN BASIS.			
13b. Design Baseline Document? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
14a. Justification (mark one) Criteria Change <input checked="" type="checkbox"/> Design Improvement <input type="checkbox"/> Environmental <input type="checkbox"/> Facility Deactivation <input type="checkbox"/> As-Found <input type="checkbox"/> Facilitate Const <input type="checkbox"/> Const. Error/Omission <input type="checkbox"/> Design Error/Omission <input type="checkbox"/>			
14b. Justification Details Minor errors discovered in the Revision 0 document have been corrected in the Revision 1 issue.			
15. Distribution (include name, MSIN, and no. of copies) See attached distribution list.			



ENGINEERING CHANGE NOTICE

15. Design Verification Required <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	16. Cost Impact <table style="width:100%;"> <tr> <th colspan="2" style="text-align: left;">ENGINEERING</th> <th colspan="2" style="text-align: left;">CONSTRUCTION</th> </tr> <tr> <td>Additional</td> <td><input type="checkbox"/> \$</td> <td>Additional</td> <td><input type="checkbox"/> \$</td> </tr> <tr> <td>Savings</td> <td><input type="checkbox"/> \$</td> <td>Savings</td> <td><input type="checkbox"/> \$</td> </tr> </table>	ENGINEERING		CONSTRUCTION		Additional	<input type="checkbox"/> \$	Additional	<input type="checkbox"/> \$	Savings	<input type="checkbox"/> \$	Savings	<input type="checkbox"/> \$	17. Schedule Impact (days) Improvement <input type="checkbox"/> Delay <input type="checkbox"/>
ENGINEERING		CONSTRUCTION												
Additional	<input type="checkbox"/> \$	Additional	<input type="checkbox"/> \$											
Savings	<input type="checkbox"/> \$	Savings	<input type="checkbox"/> \$											

18. Change Impact Review: Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 12. Enter the affected document number in Block 19.

SDD/DD	<input type="checkbox"/>	Seismic/Stress Analysis	<input type="checkbox"/>	Tank Calibration Manual	<input type="checkbox"/>
Functional Design Criteria	<input type="checkbox"/>	Stress/Design Report	<input type="checkbox"/>	Health Physics Procedure	<input type="checkbox"/>
Operating Specification	<input type="checkbox"/>	Interface Control Drawing	<input type="checkbox"/>	Spare Multiple Unit Listing	<input type="checkbox"/>
Criticality Specification	<input type="checkbox"/>	Calibration Procedure	<input type="checkbox"/>	Test Procedures/Specification	<input type="checkbox"/>
Conceptual Design Report	<input type="checkbox"/>	Installation Procedure	<input type="checkbox"/>	Component Index	<input type="checkbox"/>
Equipment Spec.	<input type="checkbox"/>	Maintenance Procedure	<input type="checkbox"/>	ASME Coded Item	<input type="checkbox"/>
Const. Spec.	<input type="checkbox"/>	Engineering Procedure	<input type="checkbox"/>	Human Factor Consideration	<input type="checkbox"/>
Procurement Spec.	<input type="checkbox"/>	Operating Instruction	<input type="checkbox"/>	Computer Software	<input type="checkbox"/>
Vendor Information	<input type="checkbox"/>	Operating Procedure	<input type="checkbox"/>	Electric Circuit Schedule	<input type="checkbox"/>
OM Manual	<input type="checkbox"/>	Operational Safety Requirement	<input type="checkbox"/>	ICRS Procedure	<input type="checkbox"/>
FSAR/SAR	<input type="checkbox"/>	IEFD Drawing	<input type="checkbox"/>	Process Control Manual/Plan	<input type="checkbox"/>
Safety Equipment List	<input type="checkbox"/>	Cell Arrangement Drawing	<input type="checkbox"/>	Process Flow Chart	<input type="checkbox"/>
Radiation Work Permit	<input type="checkbox"/>	Essential Material Specification	<input type="checkbox"/>	Purchase Requisition	<input type="checkbox"/>
Environmental Impact Statement	<input type="checkbox"/>	Fac. Proc. Samp. Schedule	<input type="checkbox"/>	Tickler File	<input type="checkbox"/>
Environmental Report	<input type="checkbox"/>	Inspection Plan	<input type="checkbox"/>	NONE	<input checked="" type="checkbox"/>
Environmental Permit	<input type="checkbox"/>	Inventory Adjustment Request	<input type="checkbox"/>		<input type="checkbox"/>

19. Other Affected Documents: (NOTE: Documents listed below will not be revised by this ECN.) Signatures below indicate that the signing organization has been notified of other affected documents listed below.

Document Number/Revision	Document Number/Revision	Document Number Revision
N/A		

20. Approvals

Signature	Date	Signature	Date
<u>OPERATIONS AND ENGINEERING</u>		<u>ARCHITECT-ENGINEER</u>	
Cog. Eng. G. W. Ryan <i>GWR</i>	<u>9/18/96</u>	PE	_____
Cog. Mgr. D. S. Leach <i>D S Leach</i>	<u>9/18/96</u>	QA	_____
QA	_____	Safety	_____
Safety	_____	Design	_____
Environ.	_____	Environ.	_____
Peer Reviewer. A.V. Savino <i>ASavino</i>	<u>9/18/96</u>	Other	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

DEPARTMENT OF ENERGY

Signature or a Control Number that tracks the Approval Signature

ADDITIONAL

Calculation Notes That Support Accident Scenario and Consequence Development for the Subsurface Leak Remaining Subsurface Accident

G. W. Ryan

Westinghouse Hanford Company, Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-87RL10930

EDT/ECN: 605030 UC: 510
Org Code: 8M100 Charge Code: N1FC3
B&R Code: EW3120071 Total Pages: 117

Key Words: transfer, pipe, pipeline, piping, tank farms, TWRS

Abstract: This document supports the development and presentation of the following accident scenario in the TWRS Final Safety Analysis Report:

Subsurface Leak Remaining Subsurface.


The calculations needed to quantify the risk associated with this accident scenario are included within.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: WHC/BCS Document Control Services, P.O. Box 1970, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Karen L. Roland
Release Approval

9/19/96
Date



Release Stamp

Approved for Public Release

**CALCULATION NOTES THAT SUPPORT ACCIDENT SCENARIO AND CONSEQUENCE DEVELOPMENT
FOR THE SUBSURFACE LEAK REMAINING SUBSURFACE ACCIDENT**

REVISION 1

**Tank Waste Remediation System Final Safety Analysis Report Project
Safety Analysis & Nuclear Engineering**

September 1996

This page intentionally left blank.

CONTENTS

1.0 INTRODUCTION AND PURPOSE 7 of 116

1.1 ACCIDENT SCENARIO DESCRIPTION 7 of 116

1.2 ACCIDENT FREQUENCY DEVELOPMENT 8 of 116

1.3 ASSUMPTIONS 8 of 116

1.4 METHODOLOGY 9 of 116

1.5 RADIOLOGICAL SOURCE TERM 9 of 116

1.6 CALCULATED RADIOLOGICAL DOSES 11 of 116

 1.6.1 Case 1 - A Horizontal Cylinder of Contaminated Soil
 is Created From the Leak 13 of 116

 1.6.2 Case 2 - A Vertical Cylinder of Contaminated Soil is
 Created From the Leak 14 of 116

 1.6.3 Case 3 - A Sphere of Contaminated Soil is Created
 From the Leak 15 of 116

1.7 RESULTS 17 of 116

1.8 CONCLUSIONS 18 of 116

1.9 REFERENCES 19 of 116

2.0 PEER REVIEW CHECKLIST 113 of 116

APPENDICES

A BREMCALC DATA 21 of 116

B MICROSHIELD OUTPUT FILES 25 of 116

Case 1 (DOS File: CASE6SEN.MS4) Output File for Direct (Line-of-Sight)
Dose Rate @ Z = 0 m, 5 m - 20 m. 27 of 116

Case 1 (DOS File: CS6BRS20.MS4) Output File for Direct (Line-of-Sight)
Bremsstrahlung Dose Rate @ Z = 0 m, 5 m - 20 m. 29 of 116

Case 1 (DOS File: CASE6100.MS4) Output File for Direct (Line-of-Sight)
Dose Rate @ Z = 100 m. 31 of 116

Case 1 (DOS File: CS6BR100.MS4) Output File for Direct (Line-of-Sight)
Bremsstrahlung Dose Rate @ Z = 100 m. 33 of 116

Case 2 (DOS File: CASE7.MS4) Output File for Direct (Line-of-Sight) Dose
Rate @ Z = 0 m. 35 of 116

Case 2 (DOS File: CASE7BR.MS4) Output File for Direct (Line-of-Sight)
Dose Bremsstrahlung Dose Rate @ Z = 0 m. 37 of 116

Case 2 (DOS File: CS7SEN20.MS4) Output File for Direct (Line-of-Sight)
Dose Rate @ Z = 5 m - 20 m. 39 of 116

Case 2 (DOS File: CS75BRSN.MS4) Output File for Direct (Line-of-Sight)
Bremsstrahlung Dose Rate @ Z = 5 m - 20 m. 41 of 116

Case 2 (DOS File: CASE7100.MS4) Output File for Direct (Line-of-Sight)
Dose Rate @ Z = 100 m. 43 of 116

Case 2 (DOS File: CS7100BR.MS4) Output File for Direct (Line-of-Sight)
Bremsstrahlung Dose Rate @ Z = 100 m. 45 of 116

Case 3 (DOS File: CASE8SEN.MS4) Output File for Direct (Line of Sight)
Dose Rate @ Z = 0 m, 5 m - 20 m. 47 of 116

Case 3 (DOS File: CS8BRSEN.MS4) Output File for Direct (Line of Sight)
Bremsstrahlung Dose Rate @ Z = 0 m, 5 m - 20 m. 49 of 116

Case 3 (DOS File: CASE8100.MS4) Output File for Direct (Line of Sight)
Dose Rate @ Z = 100 m. 51 of 116

CONTENTS (cont.)

	Case 3 (DOS File: CS8100BR.MS4) Output File for Direct (Line of Sight) Bremsstrahlung Dose Rate @ Z = 100 m.	53 of 116
C	MICROSKYSHINE OUTPUT FILES	55 of 116
	Case 1 (DOS File: CASE6SEN.SKY) Output File for Skyshine Dose Rate @ X = 5 m - 20 m.	57 of 116
	Case 1 (DOS File: CS6BRSEN.SKY) Output File for Skyshine - Bremsstrahlung Dose Rate @ X = 5 m - 20 m.	67 of 116
	Case 1 (DOS File: CASE6100.SKY) Output File for Skyshine Dose Rate @ X = 100 m.	77 of 116
	Case 1 (DOS File: CS6100BR.SKY) Output File for Skyshine - Bremsstrahlung Dose Rate @ X = 100 m.	79 of 116
	Case 2 (DOS File: CASE7SEN.SKY) Output File for Skyshine Dose Rate @ X = 5 m - 20 m.	81 of 116
	Case 2 (DOS File: CS7SENBR.SKY) Output File for Skyshine - Bremsstrahlung Dose Rate @ X = 5 m - 20 m.	91 of 116
	Case 2 (DOS File: CASE7100.SKY) Output File for Skyshine Dose Rate @ X = 100 m.	101 of 116
	Case 2 (DOS File: CS7100BR.SKY) Output File for Skyshine - Bremsstrahlung Dose Rate @ X = 100 m.	103 of 116
D	INFORMATION VALIDATION FORMS	105 of 116

LIST OF TABLES

1.5-1. The Radionuclide Concentrations of a Mix of 67 vol% SST Liquids and 33 vol% SST Solids are Calculated. 10 of 116

1.6-1. Photon Production Rates (photons/sec) for $^{90}\text{Sr}/^{90}\text{Y}$ in Both Water and Concrete Are Shown 12 of 116

1.6-2. Summary of Input Parameters for Case 1 - A Horizontal Cylinder is Created From the Leak 14 of 116

1.6-3. Summary of Input Parameters for Case 2 - A Vertical Cylinder is Created From the Leak 15 of 116

1.6-4. Summary of Input Parameters for Case 3 - A Sphere is Created From the Leak 16 of 116

1.7-1. Summary of Dose Rates* For the Three Geometries With the Receptor Directly Above Leak Point 17 of 116

1.7-2. The 12 Hour Dose For the Cylindrical Geometries are Below the Risk Guidelines When the Receptor is Located 16 m (52.5 ft) From the Leak Point. 18 of 116

1.7-3. The 12 Hour Dose For the Cylindrical Geometries are Well Below the Risk Guidelines When the Receptor is Located 100 m (328 ft) From the Leak Point. 18 of 116

LIST OF TERMS

FSAR	final safety analysis report
HEDOP	Hanford Environmental Dose Overview Panel
rem	radiation effective man
SST	single-shell tanks
Sv	sievert
TWRS	Tank Waste Remediation System
WHC	Westinghouse Hanford Company

LIST OF TRADEMARKS

BREMCALC	BREMCALC a computer program for calculating electron and positron Bremsstrahlung
MS-DOS	MS-DOS is a trademark of Microsoft Corporation
MICROSHIELD	MICROSHIELD is a registered trademark of Grove Engineering, Inc., Rockville, MD
MICROSKYSHINE	MICROSKYSHINE is a registered trademark of Grove Engineering, Inc., Rockville, MD

**CALCULATION NOTES THAT SUPPORT ACCIDENT SCENARIO AND CONSEQUENCE DEVELOPMENT
FOR THE SUBSURFACE LEAK REMAINING SUBSURFACE ACCIDENT****1.0 INTRODUCTION AND PURPOSE**

This document supports the development and presentation of the following accident scenario in the TWRS Final Safety Analysis Report (FSAR):

Subsurface Leak Remaining Subsurface.

The calculations needed to quantify the risk associated with this accident scenario are included in the following sections to aid in the understanding of this accident scenario.

Information validation forms citing assumptions that were approved for use specifically in this analysis are included in Appendix D. These forms are also on file with TWRS Project Files.

1.1 ACCIDENT SCENARIO DESCRIPTION

The hazard analysis performed for the tank farms identified causes that could result in a low energy subsurface leak that results in a subsurface plume that does not create a surface pool. Some of the causes considered included waste leaks from cracked or broken pump, valve, and related transfer pits, single-walled and encased line leaks during waste transfers (due to corrosion, structural fatigue, or other factors) or waste transfers from processing facilities to either DCRTs or diversion boxes. Also considered were the structural failures of either single-shell or double-shell tanks, DCRTs and associated containments.

Evaluation of the causes show that the radiological dose consequences associated with a subsurface plume created as a result of a low energy subsurface leak would be maximized if a leak developed during the transfer of waste slurry through single-walled, direct-buried transfer piping. This scenario is considered bounding since a leak in the transfer pipe will go directly into the soil (i.e., no encasement) and there is limited soil shielding provided due to the transfer line being direct-buried at only 1 m (3.3 ft).

In the scenario analyzed, waste slurry is transferred through a single-walled, direct-buried pipe at a maximum flow rate of ~379 L/min (100 gal/min) for 24 hours. The leak develops in the transfer pipe and releases 5% of the total volume transferred (i.e., 27,250 L [7,200 gal]). The leak volume of 5% and the assumed maximum flow rate are based on engineering judgement. Larger leak volumes may create a surface pool, which is analyzed separately (Hall 1996). The leaked waste in the scenario was assumed to create a subsurface plume and not a surface pool, thereby increasing the likelihood that the condition would remain undetectable to the facility worker.

Failure of the transfer pipe may be due to factors such as the age of the pipe, corrosion, abrasion, broken/cracked welds, etc.

1.2 ACCIDENT FREQUENCY DEVELOPMENT

The prior operational history of the tank farms and the age and condition of the transfer lines were the factors considered when a frequency of *anticipated* was qualitatively assigned to this accident scenario.

The consequences associated with this accident scenario are compared to the risk acceptance guidelines for *anticipated* accidents as provided in WHC-CM-4-46, Rev. 1.

1.3 ASSUMPTIONS

The following assumptions are considered in the analysis of this accident scenario:

- A. The subsurface leak/subsurface plume does not create a surface pool.
- B. The centerline of the single-walled buried transfer pipeline is located 1.0 m (3.3 ft) below the soil surface.
- C. The leak volume created is based on a leak of 5% of a 100 gal/min flow rate for a time period of 24 hours. Calculating produces:
 $(100 \text{ gal/min})(60 \text{ min/hr})(24 \text{ hr})(0.05) = 7,200 \text{ gal (27,250 L)}$ over 24 hours.
 This is equivalent to $(7,200 \text{ gal})/(7.48 \text{ gal/ft}^3) = 962.57 \text{ ft}^3$ of waste leaked. The metric equivalent volume is 27.25 m^3 .
- D. The source term used in this scenario is made up of 67 vol% SST Liquids and 33 vol% SST Solids (Cowley 1996 and Van Keuren 1996). The assumed density of this aqueous mixture is 1.4 g/cm^3 (87.5 lb/ft^3). This is a reasonably conservative source term for this accident scenario since only SST Liquids and Solids are transferred through single-walled buried transfer pipes.
- E. The total radiological dose to the onsite receptor from this accident scenario consists of the direct (line-of-sight), skyshine, and associated bremsstrahlung radiation components.
 There is no inhalation dose since the surface soil is not wetted by leaked waste (i.e., no resuspension of waste particles).
 The offsite receptor receives insignificant dose from this accident scenario.
- F. The receptor dose starts after the full subsurface plume has been created.
- G. There are no toxicological exposure consequences to either the onsite or offsite receptors from this accident scenario.
- H. The waste leak is assumed to contaminate the soil up to 15.24 cm (6 in) below the soil surface. Six inches of soil cover was

assumed since lesser soil cover would likely be detected or form a pool, which is analyzed separately, and greater soil cover would provide more shielding from the source and, therefore, reduce the direct, skyshine, and bremsstrahlung radiation dose consequences.

- I. The density of the soil is assumed to be 1.6 g/cm³. This value is consistent with calculations and models used in WHC-SD-WM-SARR-016, Rev. 2.

Higher density soils can be found on the Hanford Site, however, the density assumed here is considered representative and will provide conservative radiological consequence results.

- J. The soil porosity (void fraction) is assumed to be 0.40. These pores/voids are where the leaked waste resides.

A soil with a lower porosity (i.e., 0.30) was also investigated in the analysis of this accident scenario. It was found that developing the consequences with a lower void fraction would not result in conservative dose consequences since the volume of contaminated soil would be larger and therefore provide more self-shielding.

- K. No credit is taken for mass material balances during the waste transfer.
- L. The volume occupied by the transfer pipe is not subtracted from the total volume when calculating the total volume of soil contaminated by the waste leak.

1.4 METHODOLOGY

Line-of-sight and skyshine dose rate contributions were calculated using the MICROSHIELD (Grove 1992) and MICROSKYSHINE (Grove 1987) computer codes, respectively. WHC-SD-WM-SARR-016, Rev. 2 contains a description of the calculational methods used in the MICROSHIELD (line-of-sight contribution), MICROSKYSHINE (skyshine contribution), and BREMCALC (bremsstrahlung source term generation) computer codes.

1.5 RADIOLOGICAL SOURCE TERM

The source term used in this analysis is consistent with Assumption D. Evaluating the constituents of the SST Liquids/Solids source term (Cowley 1996) to develop radionuclide concentrations of 67 vol% SST Liquids and 33 vol% SST Solids produces the results presented in Table 1.5-1.

The results for specific radionuclides (i.e., Cs-137, Eu-154, Sr-90, and Y-90) from Table 1.5-1 are used (along with the total contaminated soil volume) to develop the dose consequences to the onsite receptor. Cs-137 is decayed by MICROSHIELD and MICROSKYSHINE to obtain the correct quantity of the Cs-137 daughter product, Ba-137m.

Table 1.5-1. The Radionuclide Concentrations of a Mix of 67 vol% SST Liquids and 33 vol% SST Solids are Calculated.

NUCLIDE	SST LIQUIDS	SST LIQUIDS	SST SOLIDS	SST SOLIDS	COMBINED CONCENTRATION
	CONC.	CONC. (67 vol%)	CONC.	CONC. (33 vol%)	67 vol% SST Liquids & 33 vol% SST Solids
	Bq/L	Bq/L	Bq/L	Bq/L	Bq/L
C-14	1.0 E+05	6.7 E+04	1.2 E+05	4.0 E+04	1.1 E+05
Co-60	9.5 E+06	6.4 E+06	4.2 E+08	1.4 E+08	1.4 E+08
Se-79	N/A	N/A	1.7 E+04	5.6 E+03	5.6 E+03
Sr-90	1.1 E+10	7.4 E+09	1.6 E+12	5.3 E+11	5.4 E+11
Y-90	1.1 E+10	7.4 E+09	1.6 E+12	5.3 E+11	5.4 E+11
Tc-99	1.7 E+07	1.1 E+07	1.2 E+10	4.0 E+09	4.0 E+09
Ru-106	9.9 E+02	6.6 E+02	7.2 E+04	2.4 E+04	2.5 E+04
Sb-125	3.4 E+04	2.3 E+04	1.8 E+08	5.9 E+07	5.9 E+07
I-129	1.0 E+04	6.7 E+03	6.4 E+06	2.1 E+06	2.1 E+06
Cs-134	1.2 E+05	8.0 E+04	1.4 E+06	4.6 E+05	5.4 E+05
Cs-137	2.2 E+10	1.5 E+10	1.0 E+11	3.3 E+10	4.8 E+10
Ce-144	9.1 E+00	6.1 E+00	3.4 E+02	1.1 E+02	1.2 E+02
Pm-147	N/A	N/A	N/A	N/A	N/A
Eu-154	2.4 E+09	1.6 E+09	5.8 E+09	1.9 E+09	3.5 E+09
Eu-155	5.9 E+07	4.0 E+07	5.0 E+06	1.7 E+06	4.2 E+07
Np-237	N/A	N/A	3.0 E+07	1.1 E+07	9.9 E+06
Pu-238	9.2 E+04	6.2 E+04	1.9 E+08	6.3 E+07	6.3 E+07
Pu-239/240	3.6 E+07	2.4 E+07	4.4 E+08	1.5 E+08	1.7 E+08
Pu-241	2.6 E+08	1.7 E+08	3.2 E+09	1.1 E+09	1.2 E+09
Am-241	4.2 E+07	2.8 E+07	2.3 E+08	7.6 E+07	1.0 E+08
Cm-242	N/A	N/A	N/A	N/A	N/A
Cm-244	4.2 E+05	2.8 E+05	2.3 E+06	7.6 E+05	1.0 E+06

Example calculation to show table entries for Cs-137:

$$(SST LIQUIDS CONC.)(0.67) + (SST SOLIDS CONC.)(0.33) = COMBINED CONCENTRATION$$

$$(2.2 \times 10^{10} \text{ Bq/L})(0.67) + (1.0 \times 10^{11} \text{ Bq/L})(0.33) = 4.8 \times 10^{10} \text{ Bq/L}$$

An example calculation of the source term evaluation is included here for Cs-137:

$$\begin{aligned} &(\text{Amount of Total Leak}) \times (\text{Concentration of Radionuclide}) = \text{Total Activity} \\ &(27.25 \text{ m}^3 \times 1000 \text{ L/m}^3) \times (4.8 \times 10^{10} \text{ Bq/L}) = 1.31 \times 10^{15} \text{ Bq of Cs-137} \end{aligned}$$

Assuming that the amount of waste leaked from the transfer pipe is 27.25 m³ (962.57 ft³) and the soil has a void fraction of 0.40, the contaminated soil volume is calculated to be:

$$(27.25 \text{ m}^3)/(0.40) = 68.1 \text{ m}^3$$

Combining the information provided shows that there are 1.31 x 10¹⁵ Bq of Cs-137 contained in 68.1 m³ of contaminated soil.

1.6 CALCULATED RADIOLOGICAL DOSES

While it is difficult to predict the true shape of the contaminated underground soil plume that would be created as a result of the transfer line leak, it is necessary to fashion the contaminated soil volume into a common geometric shape for computer program analysis by MICROSFIELD and MICROSKYSHINE.

Along with the applicable assumptions from Section 1.3, the following three volumetric shapes are considered in this analysis as representative of the shape of the contaminated soil volume may occupy: (1) a horizontal cylinder (leaked waste preferentially moves along the transfer line), (2) a vertical cylinder (leaked waste spreads out in a vertical cylindrical shape), and (3) a sphere (leaked waste moves in all directions from a central point).

For each assumed geometry, the radiation dose rates are calculated for a receptor located directly above the leak, and for each 1 m (3.3 ft) incremental distance from 5 m to 20 m, and at 100 m.

For the receptor located directly above the leak, two sets of MICROSFIELD runs are made to calculate the total dose rate for a receptor located directly above the pipe leak point. The first set of runs is made to calculate the dose contribution from the important gamma emitters (^{137m}Ba and ¹⁵⁴Eu) and the second set of runs is made to calculate the dose contribution from bremsstrahlung radiation produced during the decay of ⁹⁰Sr/⁹⁰Y. Note that other beta emitters are present in the source term, however ⁹⁰Sr/⁹⁰Y are the only beta emitters with a high enough activity to be a significant dose contributor.

Appendix A includes output generated by BREMCALC (Rittman 1992) of the photon production rates for 1 Ci (3.7 x 10¹⁰ Bq) of ⁹⁰Sr/⁹⁰Y, in both water and concrete. By simply ratioing the values provided in Appendix A, the photon production rates for 3.97 x 10⁹ Ci (1.47 x 10¹⁶ Bq) of ⁹⁰Sr/⁹⁰Y are tabulated in Table 1.6-1.

The ⁹⁰Sr/⁹⁰Y value is calculated by multiplying the concentration of ⁹⁰Sr/⁹⁰Y (Table 1.5-1) by the total volume leaked (Assumption C, Section 1.3):

$$(5.4 \times 10^{11} \text{ Bq/L}) \times (27,250 \text{ L}) = 1.47 \times 10^{16} \text{ Bq.}$$

Table 1.6-1. Photon Production Rates (photons/sec) for ⁹⁰Sr/⁹⁰Y in Both Water and Concrete Are Shown.

GROUP MIDPOINT ENERGY (Mev)	PRODUCTION RATE IN WATER 1 Ci Sr-90 (Appendix A)	PRODUCTION RATE IN CONCRETE 1 Ci Sr-90 (Appendix A)	PRODUCTION RATE OF 3.97 E+05 Ci Sr-90 IN WATER	PRODUCTION RATE OF 3.97 E+05 Ci Sr-90 IN CONCRETE
0.015	7.8 E+08	1.2 E+09	3.1 E+14	4.9 E+14
0.025	4.0 E+08	6.3 E+08	1.6 E+14	2.5 E+14
0.035	2.6 E+08	4.0 E+08	1.0 E+14	1.6 E+14
0.045	1.8 E+08	2.8 E+08	7.1 E+13	1.1 E+14
0.055	1.4 E+08	2.1 E+08	5.6 E+13	8.5 E+13
0.065	1.1 E+08	1.7 E+08	4.4 E+13	6.7 E+13
0.075	8.9 E+07	1.4 E+08	3.5 E+13	5.4 E+13
0.085	7.4 E+07	1.1 E+08	2.9 E+13	4.5 E+13
0.095	6.3 E+07	9.6 E+07	2.5 E+13	3.8 E+13
0.150	3.3 E+08	5.0 E+08	1.3 E+14	2.0 E+14
0.250	1.3 E+08	2.0 E+08	5.2 E+13	7.7 E+13
0.350	6.9 E+07	1.0 E+08	2.7 E+13	4.0 E+13
0.475	5.5 E+07	7.8 E+07	2.2 E+13	3.1 E+13
0.650	3.5 E+07	4.9 E+07	1.4 E+13	1.9 E+13
0.825	1.4 E+07	1.8 E+07	5.6 E+12	7.2 E+12
1.000	9.8 E+06	1.3 E+07	3.9 E+12	5.1 E+12
1.225	5.5 E+06	7.0 E+06	2.2 E+12	2.8 E+12
1.475	2.1 E+06	2.5 E+06	8.3 E+11	9.8 E+11
1.700	5.3 E+05	6.1 E+05	2.1 E+11	2.4 E+11
1.900	1.4 E+05	1.5 E+05	5.6 E+10	6.0 E+10
2.100	1.5 E+04	1.6 E+04	6.0 E+09	6.3 E+09
2.300	8.3 E+01	8.5 E+01	3.3 E+07	3.4 E+07
Totals	2.7 E+09	4.2 E+09	1.1 E+15	1.7 E+15

Since the source in this scenario is made up of a mixture of concrete (approximated for soil) and water, it is most conservative to use the photon production rate values for concrete (shaded column, Table 1.6-1) since they are higher than those of water.

Skyshine dose rates are not calculated for this scenario since the receptor is directly above the leak point. This is because the dose rate is dominated by the direct (i.e., line-of-sight) dose rate component.

Similarly, for the receptor located at 1 m (3.3 ft) incremental distances from 5 m to 20 m and at 100 m, two sets of MICROSIELD and MICROSKYSHINE runs are made. The first set of runs is made to calculate the dose contribution from the important gamma emitters (^{137m}Ba and ^{154}Eu) and the second set of runs is made to calculate the dose contribution from bremsstrahlung radiation produced during the decay of $^{90}\text{Sr}/^{90}\text{Y}$.

The calculated dimensions for each of the geometries are presented in the following sections.

1.6.1 Case 1 - A Horizontal Cylinder of Contaminated Soil is Created From the Leak

Given that the depth of the transfer pipeline is 1.0 m (3.3 ft) below the soil (Assumption B), the contaminated soil reaches a height of 15.24 cm (6 in) below the soil surface (Assumption C), and the volume of contaminated soil is 68.1 m³, the dimensions of a cylinder (on side) can be calculated.

The volume of a cylinder is calculated from the equation:

$$V = (\pi/4)d^2h$$

Considering Assumption B and assuming the cylinder is symmetrical around the leaking pipe, the diameter is calculated to be:

$$d = 2 \times (100 \text{ cm} - 15.24 \text{ cm}) = 169.52 \text{ cm} (1.6952 \text{ m})$$

The length (h) of the cylinder is calculated to be:

$$h = V/[(\pi/4)d^2] = 68.1 \text{ m}^3/[(\pi/4)(1.6952 \text{ m})^2]$$

$$h = 30.17 \text{ m} (98.96 \text{ ft})$$

The input parameters for this case are summarized in Table 1.6-2. Printed output files are included in Appendices B and C.

Table 1.6-2. Summary of Input Parameters for Case 1 - A Horizontal Cylinder is Created From the Leak.

Activity	Cs-137 activity in the contaminated soil = 1.31 E+15 Bq (4.8 E+10 Bq/L x 27,250 L), which results in an activity of 1.24 E+15 Bq Ba-137m (Ba-137m is the Cs-137 daughter product). Similarly, there are activities of 9.54 E+13 Bq Eu-154 and 1.47 E+16 Bq Sr-90/Y-90.
Geometry	A cylinder with a length of 30.17 m (98.96 ft) and radius of 0.8476 m (2.78 ft) is created from the leaked waste. This volume is symmetrically centered about the buried transfer line.
Source Material	Water with a 1.4 g/cc (87.5 lb/ft ³) density and concrete with a density of 1.6 g/cc (100 lb/ft ³).
Shield Material	Concrete with a density of 1.6 g/cc (100 lb/ft ³).
Receptor Location	A 1.5 m (~5 ft) high individual located directly above the soil surface at the center of the midpoint of the horizontal cylinder, and at 1 m (3.3 ft) incremental distances from 5 m to 20 m, and at 100 m.
Integration Parameters	MICROSHIELD - The cylindrical source was divided into 16 radial, 16 circumferential, and 16 axial kernels or segments. MICROSKYSHINE - The cylindrical source was divided into 5 radial, 5 circumferential, and 5 axial kernels or segments.

¹ Since MICROSHIELD and MICROSKYSHINE do not include "soil" in their material libraries, "soil" is modelled as concrete (which is included in both code libraries) with a density of 1.6 g/cc. This has been found to be a reasonable approximation since the elemental composition of concrete and soil are similar.

1.6.2 Case 2 - A Vertical Cylinder of Contaminated Soil is Created From the Leak

Using the same assumptions in CASE 1 with $h = 1.6952$ m (symmetry about the leaking pipe in the vertical direction) and $V = 68.1$ m³, the diameter, d , can be calculated from:

$$V = (\pi/4)d^2h$$

$$d = \text{sqrt}\{V/[(\pi/4)(h)]\}$$

$$d = \text{sqrt}\{68.1 \text{ m}^3/[(\pi/4)(1.6952 \text{ m})]\}$$

$$d = 7.15 \text{ m}$$

The input parameters for this case are summarized in Table 1.6-3. Printed output files are included in Appendices B and C.

Table 1.6-3. Summary of Input Parameters for Case 2 - A Vertical Cylinder is Created From the Leak.

Activity	Cs-137 activity in the contaminated soil = 1.31 E+15 Bq (4.8 E+10 Bq/L x 27,250 L), which results in an activity of 1.24 E+15 Bq Ba-137m (Ba-137m is the Cs-137 daughter product). Similarly, there are activities of 9.54 E+13 Bq Eu-154 and 1.47 E+16 Bq Sr-90/Y-90.
Geometry	A cylinder with a length of 1.6952 m (5.56 ft) and radius of 3.575 m (11.73 ft) is created from the leaked waste. This volume is centered about the buried transfer line.
Source Material	Water with a 1.4 g/cc (87.5 lb/ft ³) density and concrete with a density of 1.6 g/cc (100 lb/ft ³).
Shield Material	Concrete with a density of 1.6 g/cc (100 lb/ft ³).
Receptor Location	A 1.5 m (~5 ft) high individual located directly above the soil surface at the centerpoint of the vertical cylinder, and at 1 m (3.3 ft) incremental distances from 5 m to 20 m, and at 100 m.
Integration Parameters	MICROSHIELD - The cylindrical source was divided into 16 radial, 16 circumferential, and 16 axial kernels or segments. MICROSKYSHINE - The cylindrical source was divided into 5 radial, 5 circumferential, and 5 axial kernels or segments.

1.6.3 Case 3 - A Sphere of Contaminated Soil is Created From the Leak

The top of the sphere is assumed to reach a level of 15.24 cm (6 in) below the soil surface. With $V = 68.1 \text{ m}^3$, the radius of the sphere can be determined from:

$$V = 4.189 \cdot r^3$$

$$r = \text{cube root } \{V/4.189\}$$

$$r = \text{cube root } \{68.1 \text{ m}^3/4.189\}$$

$$r = 2.53 \text{ m}$$

The center of this sphere is assumed to be located at a level below the centerline of the transfer pipeline to support Assumption H. The center is located 2.6824 m (8.80 ft) below the soil surface and 1.6824 m (5.52 ft) below the centerline of the pipe.

The input parameters for this case are summarized in Table 1.6-4. Printed output files are included in Appendices B and C.

Table 1.6-4. Summary of Input Parameters for Case 3 - A Sphere is Created From the Leak.

Activity	<p>Cs-137 activity in the contaminated soil = $1.31 \text{ E}+15 \text{ Bq}$ ($4.8 \text{ E}+10 \text{ Bq/L} \times 27,250 \text{ L}$), which results in an activity of $1.24 \text{ E}+15 \text{ Bq}$ Ba-137m (Ba-137m is the Cs-137 daughter product).</p> <p>Similarly, there are activities of $9.54 \text{ E}+13 \text{ Bq}$ Eu-154 and $1.47 \text{ E}+16 \text{ Bq}$ Sr-90/Y-90.</p>
Geometry	A sphere with a radius of 2.53 m (8.30 ft) is created from the leaked waste. The center of the sphere is located 2.8624 m (8.80 ft) below the soil surface and 1.6824 m (5.52 ft) below the centerline of the pipe.
Source Material	Water with a 1.4 g/cc (87.5 lb/ft ³) density and concrete with a density of 1.6 g/cc (100 lb/ft ³).
Shield Material	Concrete with a density of 1.6 g/cc (100 lb/ft ³).
Receptor Location	A 1.5 m (~5 ft) high individual located directly above the soil surface at the center of the sphere, and at 1 m (3.3 ft) incremental distances from 5 m to 20 m, and at 100 m.
Integration Parameters	MICROSHIELD - The spherical source was divided into 16 radial and 16 angle segments.

1.7 RESULTS

The tabulated results for each case are presented in Table 1.7-1 for the receptor located directly above the leak point.

Table 1.7-1. Summary of Dose Rates* For the Three Geometries With the Receptor Directly Above Leak Point.

Dose Rate Component	Horizontal Cylinder (rem/hr)	Vertical Cylinder (rem/hr)	Sphere (rem/hr)
Line-of-Sight	3.4	18.7	3.4
Line-of-Sight Bremsstrahlung	0.3	1.6	0.3
Skyshine	N/A ¹	N/A	N/A
Skyshine Bremsstrahlung	N/A	N/A	N/A
Totals (rem/hr)	3.7	20.3	3.7
Total Dose for 12 Hours (rem) ²	44.4	243.6	44.4

* The dose rates quoted in rem/hr from MICROSHIELD and MICROSKYSHINE are actually exposure rates in air (R/hr). However, it is conservative to use the R/hr values for dose in rem/hr because the exposure-to-dose rate factors are generally less than 1. Therefore, in this document, the exposure rates from the computer codes are assumed to be equal to the dose rates.

¹ Skyshine dose rates are not calculated for this scenario since the receptor is directly above the leak point. This is because the dose rate is dominated by the direct (i.e., line-of-sight dose rate) radiation component.

² While it is not expected that a receptor would be located directly over a leak point for 12 hours, the value is shown here for consistency with the accepted methodology (i.e., calculate doses for 12 hours). The rem/hr values for each geometry can be scaled for any desired time period.

$$Sv = 100 \times rem$$

Comparing the total dose from 12 hours of exposure to the risk guidelines for an *anticipated* accident (0.5 rem) shows that for each geometry the dose to the receptor located directly above the leak point exceeds the risk guidelines.

It should be noted here that MICROSKYSHINE will not calculate the skyshine dose rate from a source in the shape of a sphere. The total dose rate for the sphere at distances greater than 0 m (0 ft) is expected to be less than the dose from the horizontal cylinder (based on a comparison of the direct dose rate output files in Appendix B). The remainder of the discussion here focuses on the horizontal and vertical cylinders.

The MICROSHIELD and MICROSKYSHINE output files in Appendices B and C are referenced to determine the distance at which the dose associated with 12 hours of exposure is below the risk guidelines for an *anticipated* accident (0.5 rem). A 12 hour dose below the risk guidelines is achievable with the receptor located at 16 m (52.5 ft) from the centerline of the horizontal pipe. Table 1.7-2 includes the pertinent information summarized from the Appendices.

Note that results presented here are conservative in that the MICROSHIELD "line-of-sight dose rate" includes a dose rate contribution from

air scatter through the buildup factors used, and the MICROSKYSHINE results also account for air scatter, although to a lesser extent for large angles of scatter. This "double counting" for the air scatter contribution to the direct dose rate was not easy to quantify, however, so the MICROSHIELD and MICROSKYSHINE results were considered to be additive.

Table 1.7-2. The 12 Hour Dose For the Cylindrical Geometries are Below the Risk Guidelines When the Receptor is Located 16 m (52.5 ft) From the Leak Point.

Dose Rate Component	Horizontal Cylinder (rem/hr)	Vertical Cylinder (rem/hr)
Line-of-Sight	1.3 E-07	4.8 E-06
Line-of-Sight Bremsstrahlung	9.0 E-09	3.6 E-07
Skyshine	3.4 E-02	4.8 E-03
Skyshine Bremsstrahlung	5.2 E-03	5.0 E-04
Totals (rem/hr)	3.9 E-02	5.3 E-03
Total Dose for 12 Hours (rem)	4.7 E-01	6.4 E-02

The 12 hour dose to a receptor at 100 m (328 ft) is below the risk guidelines with the results tabulated in Table 1.7-3.

Table 1.7-3. The 12 Hour Dose For the Cylindrical Geometries are Well Below the Risk Guidelines When the Receptor is Located 100 m (328 ft) From the Leak Point.

Dose Rate Component	Horizontal Cylinder (rem/hr)	Vertical Cylinder (rem/hr)
Line-of-Sight	7.2 E-24	7.2 E-24
Line-of-Sight Bremsstrahlung	1.9 E-24	1.9 E-24
Skyshine	4.7 E-03	6.2 E-04
Skyshine Bremsstrahlung	5.9 E-04	5.5 E-05
Totals (rem/hr)	5.3 E-03	6.8 E-04
Total Dose for 12 Hours (rem)	6.4 E-02	8.2 E-03

1.8 CONCLUSIONS

The dose rate associated with this accident scenario is unacceptable when a receptor is located directly above the leak point for a period of time as little as 1 hour (for any of the assumed geometries).

Investigating the output files shows that a 12 hour dose will be below the risk guidelines for a receptor located 16 m (52.5 ft) from the centerline of the midpoint of the horizontal cylinder.

Likewise, the 12 hour dose to a receptor located 100 m (328 ft) from the source is also below the risk guidelines.

1.9 REFERENCES

- Cowley, W. L., 1996, *Development of Radiological Concentrations and Unit Liter Doses for TWRS FSAR Radiological Consequence Calculations*, WHC-SD-WM-SARR-037, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Grove, 1987, *MICROSKYSHINE*, Grove Engineering, Inc., 15125 Shady Grove Road, Rockville, Maryland.
- Grove, 1992, *MICROSHIELD Version 4*, Grove Engineering, Inc., 15125 Shady Grove Road, Rockville, Maryland.
- Hall, B. W., 1996, *Calculation Notes for Surface Leak Resulting in a Pool, TWRS FSAR Accident Analysis*, WHC-SD-WM-CN-049, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Rittman, P. D., 1992, *BREMCALC - A Computer Program for Calculating Electron and Positron Bremsstrahlung*, WHC-SA-1435-FP, Westinghouse Hanford Company, Richland, Washington.
- Van Keuren, J. C., 1996, WHC-SD-WM-SARR-016, Rev. 2, *Tank Waste Compositions and Atmospheric Dispersion Coefficients for use in ASA Consequence Assessments*, Westinghouse Hanford Company, Richland, Washington.
- WHC, 1991, *Safety Analysis Manual*, WHC-CM-4-46, Section 4.0, Rev. 1, November 15, 1991, Westinghouse Hanford Company, Richland, Washington.

This page intentionally left blank.

APPENDIX A
BREMCALC DATA

This page intentionally left blank.

Photon Production Rates for Sr-90/Y-90 in Mixtures using BREMCALC (photons per second from 1 curie of each isotope)

Midpoint Energy	Water Z = 6.60	Paper Z = 6.35	Air Z = 7.36	Concrete Z = 10.99	AlZr Z = 33.38
0.015	7.83E+08	7.59E+08	8.56E+08	1.24E+09	3.72E+09
0.025	3.99E+08	3.87E+08	4.35E+08	6.26E+08	1.88E+09
0.035	2.56E+08	2.48E+08	2.79E+08	3.99E+08	1.19E+09
0.045	1.82E+08	1.77E+08	1.98E+08	2.83E+08	8.42E+08
0.055	1.38E+08	1.34E+08	1.50E+08	2.14E+08	6.34E+08
0.065	1.09E+08	1.06E+08	1.19E+08	1.69E+08	4.98E+08
0.075	8.91E+07	8.66E+07	9.67E+07	1.37E+08	4.03E+08
0.085	7.42E+07	7.21E+07	8.05E+07	1.14E+08	3.34E+08
0.095	6.29E+07	6.11E+07	6.82E+07	9.61E+07	2.81E+08
0.15	3.33E+08	3.24E+08	3.60E+08	5.03E+08	1.45E+09
0.25	1.32E+08	1.29E+08	1.42E+08	1.95E+08	5.50E+08
0.35	6.88E+07	6.71E+07	7.37E+07	9.98E+07	2.74E+08
0.475	5.50E+07	5.38E+07	5.87E+07	7.84E+07	2.10E+08
0.65	3.53E+07	3.46E+07	3.75E+07	4.89E+07	1.26E+08
0.825	1.36E+07	1.33E+07	1.43E+07	1.82E+07	4.49E+07
1	9.82E+06	9.66E+06	1.03E+07	1.28E+07	3.02E+07
1.225	5.54E+06	5.46E+06	5.75E+06	6.95E+06	1.53E+07
1.475	2.06E+06	2.03E+06	2.12E+06	2.46E+06	4.94E+06
1.7	5.34E+05	5.29E+05	5.45E+05	6.12E+05	1.11E+06
1.9	1.36E+05	1.35E+05	1.38E+05	1.51E+05	2.46E+05
2.1	1.49E+04	1.48E+04	1.50E+04	1.59E+04	2.31E+04
2.3	8.25E+01	8.23E+01	8.28E+01	8.51E+01	1.05E+02

This page intentionally left blank.

APPENDIX B
MICROSHIELD OUTPUT FILES

This page intentionally left blank.

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CASE6SEN.MS4
 Run Date: May 30, 1996
 Run Time: 7:18 p.m. Thursday
 Duration: 0:18:16

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Horizontal Cylinder - Receptor Directly Above Leak Point

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches	
Dose point coordinate X:	250.0	8.0	2.4
Dose point coordinate Y:	1508.5	49.0	5.9
Dose point coordinate Z:	0.0	0.0	.0
Cylinder height:	3017.0	98.0	11.8
Cylinder radius:	84.76	2.0	9.4
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80937e+7 cm³ 2404.71 cu ft. 4.15533e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE NUCLIDES

Nuclide	curies	μCi/cm ³	Nuclide	curies	μCi/cm ³
Ba-137m	3.3491e+004	4.9184e+002	Cs-137	3.5403e+004	5.1992e+002
Eu-154	2.5773e+003	3.7849e+001			

Page : 2
 DOS File: CASE6SEN.MS4
 Run Date: May 30, 1996
 Run Time: 7:18 p.m. Thursday
 Title : Horizontal Cylinder - Receptor Directly Above Leak Point

===== RESULTS FOR SENSITIVITY REFERENCE CASE (Z = 0) =====

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate		Exposure Rate In Air	
		(MeV/sq cm/sec)		(mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	3.859e+013	1.697e+001	2.792e+002	2.597e-002	4.271e-001
0.2	6.512e+012	3.809e+001	7.248e+002	6.722e-002	1.279e+000
0.4	6.803e+011	3.027e+001	3.729e+002	5.897e-002	7.266e-001
0.5	2.065e+011	1.725e+001	1.765e+002	3.387e-002	3.465e-001
0.6	1.123e+015	1.562e+005	1.366e+006	3.048e+002	2.666e+003
0.8	3.719e+013	1.148e+004	7.867e+004	2.183e+001	1.496e+002
1.0	2.934e+013	1.666e+004	9.507e+004	3.071e+001	1.752e+002
1.5	3.721e+013	6.242e+004	2.629e+005	1.050e+002	4.422e+002
TOTAL:	1.272e+015	2.468e+005	1.804e+006	4.625e+002	3.436e+003

SENSITIVITY RESULTS For: Z (cm)

Case Number	Sensitivity Variable Value	Energy Fluence Rate		Exposure Rate In Air	
		(MeV/sq cm/sec)		(mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
1	500.0	5.584e+002	7.589e+003	9.982e-001	1.404e+001
2	600.0	1.448e+002	2.126e+003	2.557e-001	3.892e+000
3	700.0	4.070e+001	6.326e+002	7.109e-002	1.145e+000
4	800.0	1.225e+001	1.993e+002	2.120e-002	3.565e-001
5	900.0	3.896e+000	6.609e+001	6.696e-003	1.169e-001
6	1000.0	1.296e+000	2.293e+001	2.216e-003	4.017e-002
7	1100.0	4.472e-001	8.272e+000	7.615e-004	1.437e-002
8	1200.0	1.589e-001	3.084e+000	2.698e-004	5.319e-003
9	1300.0	5.782e-002	1.182e+000	9.795e-005	2.027e-003
10	1400.0	2.146e-002	4.631e-001	3.629e-005	7.906e-004
11	1500.0	8.096e-003	1.847e-001	1.368e-005	3.143e-004
12	1600.0	3.097e-003	7.477e-002	5.227e-006	1.269e-004
13	1700.0	1.199e-003	3.062e-002	2.022e-006	5.186e-005
14	1800.0	4.688e-004	1.266e-002	7.903e-007	2.141e-005
15	1900.0	1.850e-004	5.277e-003	3.117e-007	8.915e-006
16	2000.0	7.358e-005	2.215e-003	1.240e-007	3.738e-006

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CS6BRS20.MS4
 Run Date: May 24, 1996
 Run Time: 1:31 p.m. Friday
 Duration: 0:45:33

File Ref: _____
 Date: / /
 By: _____
 Checked: _____

Case Title: Horizontal Cylinder - Receptor Directly Above Leak Point

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches	
Dose point coordinate X:	250.0	8.0	2.4
Dose point coordinate Y:	1508.5	49.0	5.9
Dose point coordinate Z:	0.0	0.0	.0
Cylinder height:	3017.0	98.0	11.8
Cylinder radius:	84.76	2.0	9.4
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80937e+7 cm³ 2404.71 cu ft. 4.15533e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE WAS ENTERED AS ENERGIES ONLY

Page : 2
 DOS File: CS6BRS20.MS4
 Run Date: May 24, 1996
 Run Time: 1:31 p.m. Friday
 Title : Horizontal Cylinder - Receptor Directly Above Leak Point

===== RESULTS FOR SENSITIVITY REFERENCE CASE (Z = 0) =====

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	4.900e+014	1.252e-114	2.123e-020	1.074e-115	1.821e-021
0.025	2.500e+014	1.146e-024	2.459e-020	1.977e-026	4.242e-022
0.035	1.600e+014	9.991e-009	2.557e-008	6.329e-011	1.620e-010
0.045	1.100e+014	8.549e-004	3.553e-003	2.843e-006	1.182e-005
0.055	8.500e+013	9.555e-002	6.166e-001	2.151e-004	1.388e-003
0.065	6.700e+013	9.579e-001	8.587e+000	1.739e-003	1.559e-002
0.075	5.400e+013	3.429e+000	3.891e+001	5.589e-003	6.342e-002
0.085	4.500e+013	7.552e+000	1.028e+002	1.173e-002	1.596e-001
0.095	3.800e+013	1.268e+001	1.979e+002	1.941e-002	3.029e-001
0.15	2.000e+014	4.653e+002	9.205e+003	7.663e-001	1.516e+001
0.25	7.700e+013	8.784e+002	1.510e+004	1.621e+000	2.787e+001
0.35	4.000e+013	1.214e+003	1.661e+004	2.342e+000	3.204e+001
0.475	3.100e+013	2.243e+003	2.397e+004	4.401e+000	4.703e+001
0.65	1.900e+013	3.302e+003	2.697e+004	6.411e+000	5.235e+001
0.825	7.200e+012	2.418e+003	1.616e+004	4.583e+000	3.062e+001
1.0	5.100e+012	2.896e+003	1.653e+004	5.338e+000	3.047e+001
1.225	2.800e+012	2.750e+003	1.340e+004	4.868e+000	2.371e+001
1.475	9.800e+011	1.574e+003	6.703e+003	2.659e+000	1.133e+001
1.7	2.400e+011	5.558e+002	2.157e+003	9.028e-001	3.504e+000
1.9	6.000e+010	1.840e+002	6.671e+002	2.891e-001	1.048e+000
2.1	6.300e+009	2.477e+001	8.465e+001	3.772e-002	1.289e-001
2.3	3.400e+007	1.669e-001	5.414e-001	2.468e-004	8.006e-004
TOTAL:	1.682e+015	1.853e+004	1.479e+005	3.426e+001	2.758e+002

SENSITIVITY RESULTS For: Z (cm)

Case Number	Sensitivity Variable Value	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
1	500.0	4.214e+001	5.506e+002	7.545e-002	1.010e+000
2	600.0	1.097e+001	1.560e+002	1.947e-002	2.839e-001
3	700.0	3.073e+000	4.709e+001	5.411e-003	8.503e-002
4	800.0	9.155e-001	1.501e+001	1.600e-003	2.689e-002
5	900.0	2.871e-001	5.010e+000	4.984e-004	8.906e-003
6	1000.0	9.404e-002	1.738e+000	1.622e-004	3.067e-003
7	1100.0	3.195e-002	6.229e-001	5.479e-005	1.092e-003
8	1200.0	1.120e-002	2.297e-001	1.911e-005	4.001e-004
9	1300.0	4.036e-003	8.681e-002	6.850e-006	1.503e-004
10	1400.0	1.489e-003	3.352e-002	2.516e-006	5.771e-005
11	1500.0	5.612e-004	1.319e-002	9.438e-007	2.258e-005
12	1600.0	2.154e-004	5.275e-003	3.608e-007	8.990e-006
13	1700.0	8.406e-005	2.141e-003	1.403e-007	3.633e-006
14	1800.0	3.330e-005	8.809e-004	5.536e-008	1.488e-006
15	1900.0	1.337e-005	3.667e-004	2.215e-008	6.170e-007
16	2000.0	5.433e-006	1.543e-004	8.973e-009	2.586e-007

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CASE6100.MS4
 Run Date: May 30, 1996
 Run Time: 7:00 p.m. Thursday
 Duration: 0:01:13

File Ref: _____
 Date: / /
 By: _____
 Checked: _____

Case Title: Horizontal Cylinder - Receptor 100 From Leak Point

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches	
Dose point coordinate X:	250.0	8.0	2.4
Dose point coordinate Y:	1508.5	49.0	5.9
Dose point coordinate Z:	10000.0	328.0	1.0
Cylinder height:	3017.0	98.0	11.8
Cylinder radius:	84.76	2.0	9.4
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80937e+7 cm³ 2404.71 cu ft. 4.15533e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE NUCLIDES

Nuclide	curies	μCi/cm ³	Nuclide	curies	μCi/cm ³
Ba-137m	3.3491e+004	4.9184e+002	Cs-137	3.5403e+004	5.1992e+002
Eu-154	2.5773e+003	3.7849e+001			

Page : 2
 DOS File: CASE6100.MS4
 Run Date: May 30, 1996
 Run Time: 7:00 p.m. Thursday
 Title : Horizontal Cylinder - Receptor 100 From Leak Point

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	3.859e+013	4.569e-114	1.057e-020	6.989e-117	1.617e-023
0.2	6.512e+012	2.113e-084	2.274e-020	3.729e-087	4.013e-023
0.4	6.803e+011	1.489e-065	2.867e-021	2.902e-068	5.585e-024
0.5	2.065e+011	2.386e-060	7.268e-022	4.683e-063	1.427e-024
0.6	1.123e+015	3.825e-052	3.453e-018	7.467e-055	6.740e-021
0.8	3.719e+013	6.676e-047	8.888e-020	1.270e-049	1.691e-022
1.0	2.934e+013	4.028e-042	5.398e-020	7.424e-045	9.949e-023
1.5	3.721e+013	5.973e-034	5.240e-020	1.005e-036	8.816e-023
TOTAL:	1.272e+015	5.973e-034	3.685e-018	1.005e-036	7.160e-021

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CS6BR100.MS4
 Run Date: May 24, 1996
 Run Time: 7:05 p.m. Friday
 Duration: 0:03:02

File Ref: _____
 Date: ____/____/____
 By: _____
 Checked: _____

Case Title: Horizontal Cylinder - Receptor 100 m From Leak Point - Brems

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches	
Dose point coordinate X:	250.0	8.0	2.4
Dose point coordinate Y:	1508.5	49.0	5.9
Dose point coordinate Z:	10000.0	328.0	1.0
Cylinder height:	3017.0	98.0	11.8
Cylinder radius:	84.76	2.0	9.4
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80937e+7 cm³ 2404.71 cu ft. 4.15533e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE WAS ENTERED AS ENERGIES ONLY

Page : 2
 DOS File: CS6BR100.MS4
 Run Date: May 24, 1996
 Run Time: 7:05 p.m. Friday
 Title : Horizontal Cylinder - Receptor 100 m From Leak Point - Brems

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	4.900e+014	0.000e+000	5.639e-023	0.000e+000	4.837e-024
0.025	2.500e+014	0.000e+000	6.532e-023	0.000e+000	1.127e-024
0.035	1.600e+014	0.000e+000	1.063e-022	0.000e+000	6.732e-025
0.045	1.100e+014	2.430e-295	1.832e-022	8.081e-298	6.094e-025
0.055	8.500e+013	1.086e-207	8.607e-022	2.444e-210	1.937e-024
0.065	6.700e+013	2.515e-165	2.569e-021	4.565e-168	4.664e-024
0.075	5.400e+013	6.901e-142	2.676e-021	1.125e-144	4.361e-024
0.085	4.500e+013	1.818e-127	3.688e-021	2.825e-130	5.729e-024
0.095	3.800e+013	7.907e-118	7.106e-021	1.210e-120	1.088e-023
0.15	2.000e+014	7.775e-093	3.003e-019	1.280e-095	4.945e-022
0.25	7.700e+013	1.485e-076	3.490e-019	2.741e-079	6.439e-022
0.35	4.000e+013	2.318e-067	1.792e-019	4.471e-070	3.457e-022
0.475	3.100e+013	1.842e-059	1.139e-019	3.614e-062	2.235e-022
0.65	1.900e+013	5.308e-052	5.504e-020	1.030e-054	1.068e-022
0.825	7.200e+012	6.342e-047	1.661e-020	1.202e-049	3.148e-023
1.0	5.100e+012	7.002e-043	9.384e-021	1.291e-045	1.730e-023
1.225	2.800e+012	5.973e-039	4.405e-021	1.057e-041	7.796e-024
1.475	9.800e+011	7.734e-036	1.393e-021	1.307e-038	2.355e-024
1.7	2.400e+011	6.366e-034	3.137e-022	1.034e-036	5.096e-025
1.9	6.000e+010	1.147e-032	7.402e-023	1.803e-035	1.163e-025
2.1	6.300e+009	4.623e-032	7.539e-024	7.040e-035	1.148e-026
2.3	3.400e+007	5.826e-033	4.021e-026	8.616e-036	5.946e-029
TOTAL:	1.682e+015	6.417e-032	1.047e-018	9.809e-035	1.909e-021

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CASE7.MS4
 Run Date: May 30, 1996
 Run Time: 7:18 p.m. Thursday
 Duration: 0:00:08

File Ref: _____
 Date: / /
 By: _____
 Checked: _____

Case Title: Vertical Cylinder - Receptor Directly Above Leak Point

GEOMETRY 8 - Cylinder Volume - End Shields

	centimeters	feet and inches	
Dose point coordinate X:	0.0	0.0	.0
Dose point coordinate Y:	334.76	10.0	11.8
Dose point coordinate Z:	0.0	0.0	.0
Cylinder height:	169.52	5.0	6.7
Cylinder radius:	357.5	11.0	8.7
Shield 1:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80649e+7 cm³ 2403.69 cu ft. 4.15357e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE NUCLIDES

Nuclide	curies	μCi/cm ³	Nuclide	curies	μCi/cm ³
Ba-137m	3.3491e+004	4.9205e+002	Cs-137	3.5403e+004	5.2014e+002
Eu-154	2.5773e+003	3.7865e+001			

Page : 2
 DOS File: CASE7.MS4
 Run Date: May 30, 1996
 Run Time: 7:18 p.m. Thursday
 Title : Vertical Cylinder - Receptor Directly Above Leak Point

===== RESULTS =====

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	3.859e+013	2.000e+002	2.705e+003	3.060e-001	4.138e+000
0.2	6.512e+012	3.370e+002	5.137e+003	5.948e-001	9.066e+000
0.4	6.803e+011	2.224e+002	2.250e+003	4.333e-001	4.384e+000
0.5	2.065e+011	1.201e+002	1.021e+003	2.357e-001	2.004e+000
0.6	1.123e+015	1.041e+006	7.642e+006	2.031e+003	1.492e+004
0.8	3.719e+013	7.155e+004	4.185e+005	1.361e+002	7.960e+002
1.0	2.934e+013	9.872e+004	4.868e+005	1.820e+002	8.974e+002
1.5	3.721e+013	3.383e+005	1.256e+006	5.693e+002	2.113e+003
TOTAL:	1.272e+015	1.550e+006	9.814e+006	2.920e+003	1.874e+004

Page : 1
 DOS File: CASE7BR.MS4
 Run Date: May 24, 1996
 Run Time: 8:15 p.m. Friday
 Duration: 0:00:19

File Ref: _____
 Date: / /
 By: _____
 Checked: _____

Case Title: Vertical Cylinder - Receptor Directly Above Leak Point

GEOMETRY 8 - Cylinder Volume - End Shields

	centimeters	feet and inches	
Dose point coordinate X:	0.0	0.0	.0
Dose point coordinate Y:	334.76	10.0	11.8
Dose point coordinate Z:	0.0	0.0	.0
Cylinder height:	169.52	5.0	6.7
Cylinder radius:	357.5	11.0	8.7
Shield 1:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80649e+7 cm³ 2403.69 cu ft. 4.15357e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE WAS ENTERED AS ENERGIES ONLY

Page : 2
 DOS File: CASE7BR.MS4
 Run Date: May 24, 1996
 Run Time: 8:15 p.m. Friday
 Title : Vertical Cylinder - Receptor Directly Above Leak Point

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	4.900e+014	5.636e-089	5.160e-020	4.834e-090	4.426e-021
0.025	2.500e+014	1.795e-018	2.833e-018	3.096e-020	4.886e-020
0.035	1.600e+014	7.776e-006	1.887e-005	4.926e-008	1.195e-007
0.045	1.100e+014	6.397e-002	2.422e-001	2.128e-004	8.056e-004
0.055	8.500e+013	2.851e+000	1.622e+001	6.418e-003	3.651e-002
0.065	6.700e+013	1.863e+001	1.442e+002	3.381e-002	2.618e-001
0.075	5.400e+013	5.290e+001	5.101e+002	8.621e-002	8.313e-001
0.085	4.500e+013	1.012e+002	1.153e+003	1.573e-001	1.791e+000
0.095	3.800e+013	1.548e+002	1.997e+003	2.370e-001	3.056e+000
0.15	2.000e+014	4.517e+003	7.185e+004	7.438e+000	1.183e+002
0.25	7.700e+013	7.295e+003	1.008e+005	1.346e+001	1.860e+002
0.35	4.000e+013	9.225e+003	1.029e+005	1.780e+001	1.985e+002
0.475	3.100e+013	1.580e+004	1.400e+005	3.100e+001	2.746e+002
0.65	1.900e+013	2.160e+004	1.488e+005	4.192e+001	2.888e+002
0.825	7.200e+012	1.497e+004	8.549e+004	2.837e+001	1.620e+002
1.0	5.100e+012	1.716e+004	8.464e+004	3.164e+001	1.560e+002
1.225	2.800e+012	1.558e+004	6.624e+004	2.757e+001	1.172e+002
1.475	9.800e+011	8.560e+003	3.211e+004	1.447e+001	5.427e+001
1.7	2.400e+011	2.935e+003	1.009e+004	4.767e+000	1.639e+001
1.9	6.000e+010	9.497e+002	3.064e+003	1.492e+000	4.814e+000
2.1	6.300e+009	1.253e+002	3.826e+002	1.908e-001	5.825e-001
2.3	3.400e+007	8.292e-001	2.412e+000	1.226e-003	3.567e-003
TOTAL:	1.682e+015	1.190e+005	8.502e+005	2.206e+002	1.584e+003

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CS7SEN20.MS4
 Run Date: May 30, 1996
 Run Time: 7:55 p.m. Thursday
 Duration: 0:16:16

File Ref: _____
 Date: / /
 By: _____
 Checked: _____

Case Title: Vertical Cylinder - Receptor 5 m Away From Source Center

GEOMETRY 8 - Cylinder Volume - End Shields

	centimeters	feet and inches	
Dose point coordinate X:	0.0	0.0	.0
Dose point coordinate Y:	334.76	10.0	11.8
Dose point coordinate Z:	500.0	16.0	4.9
Cylinder height:	169.52	5.0	6.7
Cylinder radius:	357.5	11.0	8.7
Shield 1:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80649e+7 cm³ 2403.69 cu ft. 4.15357e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap	Immersion Shield
Air			0.00122	
Concrete	1.6	1.6		1.6
Water	0.56			

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE NUCLIDES

Nuclide	curies	μCi/cm ³	Nuclide	curies	μCi/cm ³
Ba-137m	3.3491e+004	4.9205e+002	Cs-137	3.5403e+004	5.2014e+002
Eu-154	2.5773e+003	3.7865e+001			

Page : 2
 DOS File: CS7SEN20.MS4
 Run Date: May 30, 1996
 Run Time: 7:55 p.m. Thursday
 Title : Vertical Cylinder - Receptor 5 m Away From Source Center

===== RESULTS FOR SENSITIVITY REFERENCE CASE (Z = 500) =====

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	3.859e+013	5.297e+000	9.566e+001	8.104e-003	1.464e-001
0.2	6.512e+012	1.394e+001	3.016e+002	2.460e-002	5.323e-001
0.4	6.803e+011	1.247e+001	1.744e+002	2.431e-002	3.398e-001
0.5	2.065e+011	7.381e+000	8.520e+001	1.449e-002	1.672e-001
0.6	1.123e+015	6.884e+004	6.753e+005	1.344e+002	1.318e+003
0.8	3.719e+013	5.304e+003	4.034e+004	1.009e+001	7.673e+001
1.0	2.934e+013	7.977e+003	5.005e+004	1.470e+001	9.226e+001
1.5	3.721e+013	3.178e+004	1.446e+005	5.347e+001	2.433e+002
TOTAL:	1.272e+015	1.139e+005	9.109e+005	2.127e+002	1.732e+003

SENSITIVITY RESULTS For: Z (cm)

Case Number	Sensitivity Variable Value	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
1	600.0	2.418e+004	2.357e+005	4.465e+001	4.456e+002
2	700.0	5.298e+003	6.089e+004	9.656e+000	1.142e+002
3	800.0	1.272e+003	1.655e+004	2.287e+000	3.078e+001
4	900.0	3.338e+002	4.756e+003	5.923e-001	8.751e+000
5	1000.0	9.478e+001	1.441e+003	1.662e-001	2.622e+000
6	1100.0	2.877e+001	4.597e+002	4.996e-002	8.264e-001
7	1200.0	9.218e+000	1.537e+002	1.588e-002	2.732e-001
8	1300.0	3.088e+000	5.370e+001	5.289e-003	9.442e-002
9	1400.0	1.072e+000	1.947e+001	1.827e-003	3.392e-002
10	1500.0	3.823e-001	7.285e+000	6.496e-004	1.259e-002
11	1600.0	1.395e-001	2.799e+000	2.364e-004	4.807e-003
12	1700.0	5.181e-002	1.098e+000	8.765e-005	1.877e-003
13	1800.0	1.953e-002	4.384e-001	3.300e-005	7.464e-004
14	1900.0	7.453e-003	1.773e-001	1.258e-005	3.011e-004
15	2000.0	2.874e-003	7.250e-002	4.847e-006	1.228e-004

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CS75BRSN.MS4
 Run Date: May 24, 1996
 Run Time: 2:16 p.m. Friday
 Duration: 0:41:19

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Vertical Cylinder - Receptor 5 m Away From Source Center

GEOMETRY 8 - Cylinder Volume - End Shields

	centimeters	feet and inches	
Dose point coordinate X:	0.0	0.0	.0
Dose point coordinate Y:	334.76	10.0	11.8
Dose point coordinate Z:	500.0	16.0	4.9
Cylinder height:	169.52	5.0	6.7
Cylinder radius:	357.5	11.0	8.7
Shield 1:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80649e+7 cm³ 2403.69 cu ft. 4.15357e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap	Immersion Shield
Air			0.00122	
Concrete	1.6	1.6		1.6
Water	0.56			

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE WAS ENTERED AS ENERGIES ONLY

Page : 2
 DOS File: CS75BRSN.MS4
 Run Date: May 24, 1996
 Run Time: 2:16 p.m. Friday
 Title : Vertical Cylinder - Receptor 5 m Away From Source Center

===== RESULTS FOR SENSITIVITY REFERENCE CASE (Z = 500) =====

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	4.900e+014	1.482e-122	2.045e-020	1.272e-123	1.754e-021
0.025	2.500e+014	7.323e-027	2.369e-020	1.263e-028	4.086e-022
0.035	1.600e+014	7.982e-010	2.074e-009	5.057e-012	1.314e-011
0.045	1.100e+014	1.347e-004	5.741e-004	4.481e-007	1.909e-006
0.055	8.500e+013	2.016e-002	1.354e-001	4.538e-005	3.048e-004
0.065	6.700e+013	2.378e-001	2.252e+000	4.316e-004	4.088e-003
0.075	5.400e+013	9.401e-001	1.140e+001	1.532e-003	1.859e-002
0.085	4.500e+013	2.210e+000	3.253e+001	3.434e-003	5.053e-002
0.095	3.800e+013	3.885e+000	6.628e+001	5.946e-003	1.014e-001
0.15	2.000e+014	1.613e+002	3.590e+003	2.656e-001	5.911e+000
0.25	7.700e+013	3.343e+002	6.558e+003	6.167e-001	1.210e+001
0.35	4.000e+013	4.891e+002	7.617e+003	9.435e-001	1.469e+001
0.475	3.100e+013	9.514e+002	1.149e+004	1.867e+000	2.254e+001
0.65	1.900e+013	1.475e+003	1.347e+004	2.864e+000	2.615e+001
0.825	7.200e+012	1.123e+003	8.315e+003	2.128e+000	1.576e+001
1.0	5.100e+012	1.387e+003	8.701e+003	2.556e+000	1.604e+001
1.225	2.800e+012	1.359e+003	7.215e+003	2.406e+000	1.277e+001
1.475	9.800e+011	7.992e+002	3.682e+003	1.351e+000	6.223e+000
1.7	2.400e+011	2.879e+002	1.202e+003	4.676e-001	1.952e+000
1.9	6.000e+010	9.673e+001	3.755e+002	1.520e-001	5.899e-001
2.1	6.300e+009	1.318e+001	4.806e+001	2.008e-002	7.318e-002
2.3	3.400e+007	8.981e-002	3.097e-001	1.328e-004	4.580e-004
TOTAL:	1.682e+015	8.485e+003	7.238e+004	1.565e+001	1.350e+002

SENSITIVITY RESULTS For: Z (cm)

Case Number	Sensitivity Variable Value	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
1	600.0	1.786e+003	1.769e+004	3.270e+000	3.293e+001
2	700.0	3.941e+002	4.435e+003	7.152e-001	8.217e+000
3	800.0	9.568e+001	1.198e+003	1.720e-001	2.205e+000
4	900.0	2.529e+001	3.470e+002	4.505e-002	6.338e-001
5	1000.0	7.177e+000	1.067e+002	1.268e-002	1.934e-001
6	1100.0	2.162e+000	3.452e+001	3.789e-003	6.203e-002
7	1200.0	6.835e-001	1.165e+001	1.189e-003	2.077e-002
8	1300.0	2.254e-001	4.077e+000	3.896e-004	7.216e-003
9	1400.0	7.694e-002	1.472e+000	1.322e-004	2.586e-003
10	1500.0	2.705e-002	5.452e-001	4.621e-005	9.518e-004
11	1600.0	9.754e-003	2.066e-001	1.658e-005	3.584e-004
12	1700.0	3.596e-003	7.984e-002	6.082e-006	1.377e-004
13	1800.0	1.352e-003	3.139e-002	2.276e-006	5.385e-005
14	1900.0	5.169e-004	1.253e-002	8.666e-007	2.138e-005
15	2000.0	2.008e-004	5.072e-003	3.352e-007	8.613e-006

Page : 1
 DOS File: CASE7100.MS4
 Run Date: May 30, 1996
 Run Time: 7:20 p.m. Thursday
 Duration: 0:01:13

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Vertical Cylinder - Receptor 100 m From Leak Point

GEOMETRY 8 - Cylinder Volume - End Shields

	centimeters	feet and inches	
Dose point coordinate X:	0.0	0.0	.0
Dose point coordinate Y:	334.76	10.0	11.8
Dose point coordinate Z:	10000.0	328.0	1.0
Cylinder height:	169.52	5.0	6.7
Cylinder radius:	357.5	11.0	8.7
Shield 1:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80649e+7 cm³ 2403.69 cu ft. 4.15357e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap	Immersion Shield
Air			0.00122	
Concrete	1.6	1.6		1.6
Water	0.56			

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci/cm}^3$	Nuclide	curies	$\mu\text{Ci/cm}^3$
Ba-137m	3.3491e+004	4.9205e+002	Cs-137	3.5403e+004	5.2014e+002
Eu-154	2.5773e+003	3.7865e+001			

Page : 2
 DOS File: CASE7100.MS4
 Run Date: May 30, 1996
 Run Time: 7:20 p.m. Thursday
 Title : Vertical Cylinder - Receptor 100 m From Leak Point

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	3.859e+013	7.115e-113	1.066e-020	1.089e-115	1.631e-023
0.2	6.512e+012	1.462e-083	2.292e-020	2.580e-086	4.046e-023
0.4	6.803e+011	6.787e-065	2.890e-021	1.322e-067	5.631e-024
0.5	2.065e+011	9.947e-060	7.327e-022	1.952e-062	1.438e-024
0.6	1.123e+015	1.509e-051	3.481e-018	2.946e-054	6.794e-021
0.8	3.719e+013	2.496e-046	8.960e-020	4.747e-049	1.704e-022
1.0	2.934e+013	1.486e-041	5.441e-020	2.740e-044	1.003e-022
1.5	3.721e+013	2.290e-033	5.282e-020	3.853e-036	8.888e-023
TOTAL:	<u>1.272e+015</u>	<u>2.290e-033</u>	<u>3.715e-018</u>	<u>3.853e-036</u>	<u>7.218e-021</u>

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CS7100BR.MS4
 Run Date: May 24, 1996
 Run Time: 1:34 p.m. Friday
 Duration: 0:03:04

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Vertical Cylinder - Receptor 100 m From Leak Point - Bremss

GEOMETRY 8 - Cylinder Volume - End Shields

	centimeters	feet and inches	
Dose point coordinate X:	0.0	0.0	.0
Dose point coordinate Y:	334.76	10.0	11.8
Dose point coordinate Z:	10000.0	328.0	1.0
Cylinder height:	169.52	5.0	6.7
Cylinder radius:	357.5	11.0	8.7
Shield 1:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.80649e+7 cm³ 2403.69 cu ft. 4.15357e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Slab	Air Gap	Immersion Shield
Air			0.00122	
Concrete	1.6	1.6		1.6
Water	0.56			

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Circumferential	16
Axial (along Z)	16

SOURCE WAS ENTERED AS ENERGIES ONLY

Page : 2
 DOS File: CS7100BR.MS4
 Run Date: May 24, 1996
 Run Time: 1:34 p.m. Friday
 Title : Vertical Cylinder - Receptor 100 m From Leak Point - Bremss

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	4.900e+014	0.000e+000	5.685e-023	0.000e+000	4.876e-024
0.025	2.500e+014	0.000e+000	6.585e-023	0.000e+000	1.136e-024
0.035	1.600e+014	0.000e+000	1.071e-022	0.000e+000	6.786e-025
0.045	1.100e+014	8.076e-292	1.847e-022	2.686e-294	6.144e-025
0.055	8.500e+013	2.639e-205	8.677e-022	5.939e-208	1.953e-024
0.065	6.700e+013	1.742e-163	2.590e-021	3.161e-166	4.701e-024
0.075	5.400e+013	2.400e-140	2.698e-021	3.912e-143	4.397e-024
0.085	4.500e+013	4.157e-126	3.718e-021	6.458e-129	5.776e-024
0.095	3.800e+013	1.370e-116	7.164e-021	2.096e-119	1.096e-023
0.15	2.000e+014	6.907e-092	3.027e-019	1.137e-094	4.985e-022
0.25	7.700e+013	8.777e-076	3.519e-019	1.619e-078	6.492e-022
0.35	4.000e+013	1.126e-066	1.807e-019	2.173e-069	3.485e-022
0.475	3.100e+013	7.822e-059	1.149e-019	1.535e-061	2.254e-022
0.65	1.900e+013	2.055e-051	5.548e-020	3.989e-054	1.077e-022
0.825	7.200e+012	2.363e-046	1.675e-020	4.478e-049	3.173e-023
1.0	5.100e+012	2.584e-042	9.460e-021	4.764e-045	1.744e-023
1.225	2.800e+012	2.226e-038	4.440e-021	3.940e-041	7.859e-024
1.475	9.800e+011	2.956e-035	1.405e-021	4.996e-038	2.374e-024
1.7	2.400e+011	2.504e-033	3.163e-022	4.067e-036	5.137e-025
1.9	6.000e+010	4.634e-032	7.462e-023	7.281e-035	1.172e-025
2.1	6.300e+009	1.917e-031	7.600e-024	2.920e-034	1.157e-026
2.3	3.400e+007	2.479e-032	4.053e-026	3.666e-035	5.994e-029
TOTAL:	1.682e+015	2.654e-031	1.055e-018	4.055e-034	1.924e-021

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CASE8SEN.MS4
 Run Date: May 30, 1996
 Run Time: 7:39 p.m. Thursday
 Duration: 0:18:07

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Sphere - Receptor Directly Above Leak Point

GEOMETRY 6 - Sphere Volume

	centimeters	feet and inches	
Dose point coordinate X:	418.24	13.0	8.7
Dose point coordinate Y:	0.0	0.0	.0
Dose point coordinate Z:	0.0	0.0	.0
Sphere radius:	253.0	8.0	3.6
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.78344e+7 cm³ 2395.55 cu ft. 4.13951e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Radial Angle	Quadrature Order
		16
		16

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	3.3491e+004	4.9372e+002	Cs-137	3.5403e+004	5.2191e+002
Eu-154	2.5773e+003	3.7993e+001			

Page : 2
 DOS File: CASE8SEN.MS4
 Run Date: May 30, 1996
 Run Time: 7:39 p.m. Thursday
 Title : Sphere - Receptor Directly Above Leak Point

===== RESULTS FOR SENSITIVITY REFERENCE CASE (Z = 0) =====

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	3.859e+013	2.903e+001	4.085e+002	4.441e-002	6.249e-001
0.2	6.512e+012	5.169e+001	8.288e+002	9.123e-002	1.463e+000
0.4	6.803e+011	3.564e+001	3.845e+002	6.944e-002	7.492e-001
0.5	2.065e+011	1.956e+001	1.780e+002	3.839e-002	3.494e-001
0.6	1.123e+015	1.720e+005	1.356e+006	3.357e+002	2.646e+003
0.8	3.719e+013	1.213e+004	7.646e+004	2.308e+001	1.454e+002
1.0	2.934e+013	1.713e+004	9.114e+004	3.157e+001	1.680e+002
1.5	3.721e+013	6.155e+004	2.472e+005	1.036e+002	4.158e+002
TOTAL:	<u>1.272e+015</u>	<u>2.629e+005</u>	<u>1.772e+006</u>	<u>4.941e+002</u>	<u>3.379e+003</u>

SENSITIVITY RESULTS For: Z (cm)

Case Number	Sensitivity Variable Value	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
1	500.0	1.571e+002	2.244e+003	2.787e-001	4.128e+000
2	600.0	3.107e+001	4.764e+002	5.443e-002	8.655e-001
3	700.0	6.868e+000	1.110e+002	1.190e-002	1.990e-001
4	800.0	1.658e+000	2.807e+001	2.849e-003	4.968e-002
5	900.0	4.288e-001	7.611e+000	7.324e-004	1.332e-002
6	1000.0	1.170e-001	2.188e+000	1.989e-004	3.791e-003
7	1100.0	3.329e-002	6.599e-001	5.643e-005	1.135e-003
8	1200.0	9.794e-003	2.068e-001	1.657e-005	3.535e-004
9	1300.0	2.961e-003	6.678e-002	5.001e-006	1.137e-004
10	1400.0	9.152e-004	2.208e-002	1.544e-006	3.747e-005
11	1500.0	2.883e-004	7.440e-003	4.861e-007	1.260e-005
12	1600.0	9.225e-005	2.545e-003	1.555e-007	4.301e-006
13	1700.0	2.993e-005	8.812e-004	5.042e-008	1.488e-006
14	1800.0	9.826e-006	3.082e-004	1.655e-008	5.199e-007
15	1900.0	3.260e-006	1.087e-004	5.489e-009	1.833e-007
16	2000.0	1.092e-006	3.864e-005	1.838e-009	6.511e-008

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CS8BRSEN.MS4
 Run Date: May 24, 1996
 Run Time: 3:23 p.m. Friday
 Duration: 0:47:18

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Sphere - Receptor Directly Above Leak Point

GEOMETRY 6 - Sphere Volume

	centimeters	feet and inches	
Dose point coordinate X:	418.24	13.0	8.7
Dose point coordinate Y:	0.0	0.0	.0
Dose point coordinate Z:	0.0	0.0	.0
Sphere radius:	253.0	8.0	3.6
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.78344e+7 cm³ 2395.55 cu ft. 4.13951e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Angle	16

SOURCE WAS ENTERED AS ENERGIES ONLY

Page : 2
 DOS File: CS8BRSEN.MS4
 Run Date: May 24, 1996
 Run Time: 3:23 p.m. Friday
 Title : Sphere - Receptor Directly Above Leak Point

===== RESULTS FOR SENSITIVITY REFERENCE CASE (Z = 0) =====

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	4.900e+014	4.835e-100	3.535e-020	4.147e-101	3.032e-021
0.025	2.500e+014	2.288e-021	4.437e-020	3.947e-023	7.653e-022
0.035	1.600e+014	2.645e-007	6.581e-007	1.676e-009	4.169e-009
0.045	1.100e+014	5.481e-003	2.158e-002	1.823e-005	7.178e-005
0.055	8.500e+013	3.309e-001	1.967e+000	7.447e-004	4.426e-003
0.065	6.700e+013	2.427e+000	1.959e+001	4.405e-003	3.556e-002
0.075	5.400e+013	7.270e+000	7.300e+000	1.185e-002	1.190e-001
0.085	4.500e+013	1.433e+001	1.698e+002	2.226e-002	2.637e-001
0.095	3.800e+013	2.232e+001	2.995e+002	3.416e-002	4.584e-001
0.15	2.000e+014	6.802e+002	1.132e+004	1.120e+000	1.864e+001
0.25	7.700e+013	1.134e+003	1.656e+004	2.093e+000	3.055e+001
0.35	4.000e+013	1.465e+003	1.739e+004	2.826e+000	3.354e+001
0.475	3.100e+013	2.564e+003	2.428e+004	5.030e+000	4.765e+001
0.65	1.900e+013	3.593e+003	2.660e+004	6.976e+000	5.165e+001
0.825	7.200e+012	2.546e+003	1.567e+004	4.825e+000	2.970e+001
1.0	5.100e+012	2.977e+003	1.584e+004	5.488e+000	2.921e+001
1.225	2.800e+012	2.765e+003	1.271e+004	4.894e+000	2.249e+001
1.475	9.800e+011	1.554e+003	6.307e+003	2.626e+000	1.066e+001
1.7	2.400e+011	5.424e+002	2.019e+003	8.809e-001	3.279e+000
1.9	6.000e+010	1.781e+002	6.219e+002	2.798e-001	9.771e-001
2.1	6.300e+009	2.381e+001	7.867e+001	3.625e-002	1.198e-001
2.3	3.400e+007	1.595e-001	5.019e-001	2.359e-004	7.423e-004
TOTAL:	1.682e+015	2.007e+004	1.500e+005	3.715e+001	2.793e+002

SENSITIVITY RESULTS For: Z (cm)

Case Number	Sensitivity Variable Value	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
1	500.0	1.189e+001	1.636e+002	2.119e-002	2.987e-001
2	600.0	2.353e+000	3.529e+001	4.152e-003	6.388e-002
3	700.0	5.151e-001	8.353e+000	9.013e-004	1.499e-002
4	800.0	1.223e-001	2.131e+000	2.124e-004	3.790e-003
5	900.0	3.104e-002	5.777e-001	5.348e-005	1.019e-003
6	1000.0	8.314e-003	1.646e-001	1.423e-005	2.880e-004
7	1100.0	2.331e-003	4.890e-002	3.965e-006	8.494e-005
8	1200.0	6.794e-004	1.505e-002	1.149e-006	2.597e-005
9	1300.0	2.047e-004	4.776e-003	3.445e-007	8.188e-006
10	1400.0	6.351e-005	1.556e-003	1.064e-007	2.652e-006
11	1500.0	2.021e-005	5.187e-004	3.369e-008	8.793e-007
12	1600.0	6.577e-006	1.765e-004	1.092e-008	2.977e-007
13	1700.0	2.184e-006	6.114e-005	3.612e-009	1.026e-007
14	1800.0	7.383e-007	2.153e-005	1.216e-009	3.597e-008
15	1900.0	2.536e-007	7.689e-006	4.165e-010	1.280e-008
16	2000.0	8.844e-008	2.783e-006	1.447e-010	4.614e-009

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CASE8100.MS4
 Run Date: May 30, 1996
 Run Time: 7:21 p.m. Thursday
 Duration: 0:01:12

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Sphere - Receptor 100 m From Leak Point

GEOMETRY 6 - Sphere Volume

	centimeters	feet and inches	
Dose point coordinate X:	418.24	13.0	8.7
Dose point coordinate Y:	0.0	0.0	.0
Dose point coordinate Z:	10000.0	328.0	1.0
Sphere radius:	253.0	8.0	3.6
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.78344e+7 cm³ 2395.55 cu ft. 4.13951e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Angle	16

SOURCE NUCLIDES

Nuclide	curies	μCi/cm ³	Nuclide	curies	μCi/cm ³
Ba-137m	3.3491e+004	4.9372e+002	Cs-137	3.5403e+004	5.2191e+002
Eu-154	2.5773e+003	3.7993e+001			

Page : 2
 DOS File: CASE8100.MS4
 Run Date: May 30, 1996
 Run Time: 7:21 p.m. Thursday
 Title : Sphere - Receptor 100 m From Leak Point

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	3.859e+013	1.711e-138	1.064e-020	2.618e-141	1.628e-023
0.2	6.512e+012	1.829e-102	2.289e-020	3.228e-105	4.039e-023
0.4	6.803e+011	1.763e-079	2.885e-021	3.435e-082	5.622e-024
0.5	2.065e+011	4.395e-073	7.316e-022	8.627e-076	1.436e-024
0.6	1.123e+015	6.005e-064	3.475e-018	1.172e-066	6.784e-021
0.8	3.719e+013	2.620e-057	8.946e-020	4.983e-060	1.702e-022
1.0	2.934e+013	1.632e-051	5.433e-020	3.009e-054	1.001e-022
1.5	3.721e+013	1.132e-041	5.274e-020	1.905e-044	8.873e-023
TOTAL:	1.272e+015	1.132e-041	3.709e-018	1.905e-044	7.206e-021

MicroShield 4.00 - Serial #4.00-00128

Westinghouse Hanford Company

Page : 1
 DOS File: CS8100BR.MS4
 Run Date: May 24, 1996
 Run Time: 2:36 p.m. Friday
 Duration: 0:03:02

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

Case Title: Sphere - Receptor 100 m From Leak Point - Bremss

GEOMETRY 6 - Sphere Volume

	centimeters	feet and inches	
Dose point coordinate X:	418.24	13.0	8.7
Dose point coordinate Y:	0.0	0.0	.0
Dose point coordinate Z:	10000.0	328.0	1.0
Sphere radius:	253.0	8.0	3.6
Transition:	15.24	0.0	6.0
Air Gap:	150.0	4.0	11.1

Source Volume: 6.78344e+7 cm³ 2395.55 cu ft. 4.13951e+6 cu in.

MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Transition Shield	Air Gap
Air			0.00122
Concrete	1.6	1.6	
Water	0.56		

BUILDUP

Method: Buildup Factor Tables
 The material reference is Transition

INTEGRATION PARAMETERS

	Quadrature Order
Radial	16
Angle	16

SOURCE WAS ENTERED AS ENERGIES ONLY

Page : 2
 DOS File: CS8100BR.MS4
 Run Date: May 24, 1996
 Run Time: 2:36 p.m. Friday
 Title : Sphere - Receptor 100 m From Leak Point - Bremss

===== RESULTS =====					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
		No Buildup	With Buildup	No Buildup	With Buildup
0.015	4.900e+014	0.000e+000	5.676e-023	0.000e+000	4.868e-024
0.025	2.500e+014	0.000e+000	6.574e-023	0.000e+000	1.134e-024
0.035	1.600e+014	0.000e+000	1.070e-022	0.000e+000	6.775e-025
0.045	1.100e+014	0.000e+000	1.844e-022	0.000e+000	6.134e-025
0.055	8.500e+013	7.209e-252	8.663e-022	1.622e-254	1.950e-024
0.065	6.700e+013	1.452e-200	2.586e-021	2.635e-203	4.694e-024
0.075	5.400e+013	3.515e-172	2.693e-021	5.729e-175	4.389e-024
0.085	4.500e+013	1.024e-154	3.712e-021	1.590e-157	5.766e-024
0.095	3.800e+013	4.839e-143	7.153e-021	7.405e-146	1.095e-023
0.15	2.000e+014	5.704e-113	3.022e-019	9.394e-116	4.977e-022
0.25	7.700e+013	3.332e-093	3.513e-019	6.147e-096	6.481e-022
0.35	4.000e+013	4.928e-082	1.804e-019	9.506e-085	3.479e-022
0.475	3.100e+013	1.829e-072	1.147e-019	3.589e-075	2.250e-022
0.65	1.900e+013	2.084e-063	5.539e-020	4.046e-066	1.075e-022
0.825	7.200e+012	3.463e-057	1.672e-020	6.563e-060	3.168e-023
1.0	5.100e+012	2.838e-052	9.445e-021	5.231e-055	1.741e-023
1.225	2.800e+012	1.789e-047	4.433e-021	3.167e-050	7.847e-024
1.475	9.800e+011	1.266e-043	1.402e-021	2.140e-046	2.370e-024
1.7	2.400e+011	3.456e-041	3.157e-022	5.614e-044	5.129e-025
1.9	6.000e+010	1.500e-039	7.450e-023	2.357e-042	1.171e-025
2.1	6.300e+009	1.276e-038	7.588e-024	1.943e-041	1.155e-026
2.3	3.400e+007	3.059e-039	4.047e-026	4.524e-042	5.985e-029
TOTAL:	1.682e+015	1.735e-038	1.054e-018	2.636e-041	1.921e-021

APPENDIX C
MICROSKYSHINE OUTPUT FILES

This page intentionally left blank.

MicroSkyshine

=====

(Nuclear & Radiological Safety Analysis - 1.16-007)

Page: 1	File Ref: _____
File: CASE6SEN.SKY	Date: ___/___/___
Run: 6:23 a.m.	By: _____
: May 31, 1996	Checked: _____

CASE: SKYSHINE @ 5M FROM MIDPOINT OF PIPE CENTERLINE

GEOMETRY: Horizontal cylinder source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	5.
Depth of source behind wall.....	Y	1.01
Offset of detector.....	Z	-15.085
Depth of dose point.....	H	-0.5
Distance between source and wall.....	R1	0.01
Distance between near source edge and wall...	R2	1.6952
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	0.8476
Length of source.....	L	30.17

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Length Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
-----	-----	-----	-----
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

Page 2

CASE: SKYSHINE @ 5M FROM MIDPOINT OF PIPE CENTERLINE

SOURCE NUCLIDES:

Nuclide	Curies	Nuclide	Curies
Ba-137m	3.3491e+04	Cs-137	3.5403e+04
Eu-154	2.5773e+03		

RESULTS OF SENSITIVITY STUDY ON DIMENSION X - REFERENCE CASE:

Reference case value: 5

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.684e-20	2.651e+00
2	1.01	2.757e+13	1.494e-20	1.699e+00
3	.84	1.751e+13	1.269e-20	9.161e-01
4	.66	1.143e+15	1.190e-20	5.608e+01
5	.48	9.308e+11	1.019e-20	3.912e-02
6	.40	1.997e+11	8.429e-21	6.941e-03
7	.24	6.296e+12	6.850e-21	1.778e-01
8	.20	2.166e+11	5.577e-21	4.981e-03
9	.12	3.859e+13	1.748e-21	2.781e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		6.185e+01

RESULTS FOR SENSITIVITY ITERATION 1 OF 15 (DIMENSION X = 6):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.547e-20	2.435e+00
2	1.01	2.757e+13	1.378e-20	1.566e+00
3	.84	1.751e+13	1.172e-20	8.459e-01
4	.66	1.143e+15	1.103e-20	5.199e+01
5	.48	9.308e+11	9.488e-21	3.642e-02
6	.40	1.997e+11	7.855e-21	6.468e-03
7	.24	6.296e+12	6.387e-21	1.658e-01
8	.20	2.166e+11	5.199e-21	4.644e-03
9	.12	3.859e+13	1.629e-21	2.593e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		5.731e+01

RESULTS FOR SENSITIVITY ITERATION 2 OF 15 (DIMENSION X = 7):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.434e-20	2.258e+00
2	1.01	2.757e+13	1.281e-20	1.456e+00
3	.84	1.751e+13	1.090e-20	7.873e-01
4	.66	1.143e+15	1.030e-20	4.855e+01
5	.48	9.308e+11	8.885e-21	3.410e-02
6	.40	1.997e+11	7.361e-21	6.062e-03
7	.24	6.296e+12	5.981e-21	1.553e-01
8	.20	2.166e+11	4.868e-21	4.348e-03
9	.12	3.859e+13	1.525e-21	2.427e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		5.349e+01

RESULTS FOR SENSITIVITY ITERATION 3 OF 15 (DIMENSION X = 8):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.337e-20	2.106e+00
2	1.01	2.757e+13	1.198e-20	1.362e+00
3	.84	1.751e+13	1.021e-20	7.369e-01
4	.66	1.143e+15	9.666e-21	4.555e+01
5	.48	9.308e+11	8.357e-21	3.207e-02
6	.40	1.997e+11	6.928e-21	5.705e-03
7	.24	6.296e+12	5.622e-21	1.459e-01
8	.20	2.166e+11	4.573e-21	4.085e-03
9	.12	3.859e+13	1.432e-21	2.279e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		5.017e+01

RESULTS FOR SENSITIVITY ITERATION 4 OF 15 (DIMENSION X = 9):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.254e-20	1.975e+00
2	1.01	2.757e+13	1.126e-20	1.279e+00
3	.84	1.751e+13	9.598e-21	6.930e-01
4	.66	1.143e+15	9.108e-21	4.292e+01
5	.48	9.308e+11	7.889e-21	3.028e-02
6	.40	1.997e+11	6.543e-21	5.388e-03
7	.24	6.296e+12	5.299e-21	1.376e-01
8	.20	2.166e+11	4.308e-21	3.848e-03
9	.12	3.859e+13	1.349e-21	2.146e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.726e+01

RESULTS FOR SENSITIVITY ITERATION 5 OF 15 (DIMENSION X = 10):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.181e-20	1.860e+00
2	1.01	2.757e+13	1.062e-20	1.207e+00
3	.84	1.751e+13	9.062e-21	6.542e-01
4	.66	1.143e+15	8.612e-21	4.059e+01
5	.48	9.308e+11	7.470e-21	2.867e-02
6	.40	1.997e+11	6.198e-21	5.104e-03
7	.24	6.296e+12	5.008e-21	1.300e-01
8	.20	2.166e+11	4.069e-21	3.635e-03
9	.12	3.859e+13	1.273e-21	2.025e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.468e+01

RESULTS FOR SENSITIVITY ITERATION 6 OF 15 (DIMENSION X = 11):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.117e-20	1.759e+00
2	1.01	2.757e+13	1.005e-20	1.143e+00
3	.84	1.751e+13	8.583e-21	6.197e-01
4	.66	1.143e+15	8.168e-21	3.849e+01
5	.48	9.308e+11	7.092e-21	2.722e-02
6	.40	1.997e+11	5.887e-21	4.848e-03
7	.24	6.296e+12	4.744e-21	1.232e-01
8	.20	2.166e+11	3.852e-21	3.440e-03
9	.12	3.859e+13	1.204e-21	1.916e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.236e+01

RESULTS FOR SENSITIVITY ITERATION 7 OF 15 (DIMENSION X = 12):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.059e-20	1.668e+00
2	1.01	2.757e+13	9.546e-21	1.085e+00
3	.84	1.751e+13	8.154e-21	5.887e-01
4	.66	1.143e+15	7.767e-21	3.660e+01
5	.48	9.308e+11	6.750e-21	2.591e-02
6	.40	1.997e+11	5.604e-21	4.615e-03
7	.24	6.296e+12	4.503e-21	1.169e-01
8	.20	2.166e+11	3.653e-21	3.263e-03
9	.12	3.859e+13	1.141e-21	1.815e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.028e+01

RESULTS FOR SENSITIVITY ITERATION 8 OF 15 (DIMENSION X = 13):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.007e-20	1.586e+00
2	1.01	2.757e+13	9.088e-21	1.033e+00
3	.84	1.751e+13	7.765e-21	5.606e-01
4	.66	1.143e+15	7.402e-21	3.489e+01
5	.48	9.308e+11	6.437e-21	2.471e-02
6	.40	1.997e+11	5.345e-21	4.402e-03
7	.24	6.296e+12	4.283e-21	1.112e-01
8	.20	2.166e+11	3.471e-21	3.101e-03
9	.12	3.859e+13	1.083e-21	1.724e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		3.838e+01

Page 7

RESULTS FOR SENSITIVITY ITERATION 9 OF 15 (DIMENSION X = 14):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	9.605e-21	1.512e+00
2	1.01	2.757e+13	8.671e-21	9.858e-01
3	.84	1.751e+13	7.412e-21	5.351e-01
4	.66	1.143e+15	7.070e-21	3.332e+01
5	.48	9.308e+11	6.151e-21	2.361e-02
6	.40	1.997e+11	5.108e-21	4.206e-03
7	.24	6.296e+12	4.080e-21	1.059e-01
8	.20	2.166e+11	3.304e-21	2.951e-03
9	.12	3.859e+13	1.030e-21	1.639e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		3.665e+01

RESULTS FOR SENSITIVITY ITERATION 10 OF 15 (DIMENSION X = 15):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	9.177e-21	1.445e+00
2	1.01	2.757e+13	8.292e-21	9.426e-01
3	.84	1.751e+13	7.090e-21	5.119e-01
4	.66	1.143e+15	6.765e-21	3.188e+01
5	.48	9.308e+11	5.887e-21	2.260e-02
6	.40	1.997e+11	4.890e-21	4.026e-03
7	.24	6.296e+12	3.892e-21	1.010e-01
8	.20	2.166e+11	3.149e-21	2.813e-03
9	.12	3.859e+13	9.809e-22	1.561e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		3.507e+01

RESULTS FOR SENSITIVITY ITERATION 11 OF 15 (DIMENSION X = 16):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	8.786e-21	1.384e+00
2	1.01	2.757e+13	7.943e-21	9.029e-01
3	.84	1.751e+13	6.793e-21	4.904e-01
4	.66	1.143e+15	6.484e-21	3.056e+01
5	.48	9.308e+11	5.644e-21	2.166e-02
6	.40	1.997e+11	4.688e-21	3.860e-03
7	.24	6.296e+12	3.719e-21	9.654e-02
8	.20	2.166e+11	3.006e-21	2.685e-03
9	.12	3.859e+13	9.354e-22	1.488e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

TOTALS: 1.272e+15 3.361e+01

RESULTS FOR SENSITIVITY ITERATION 12 OF 15 (DIMENSION X = 17):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	8.425e-21	1.327e+00
2	1.01	2.757e+13	7.621e-21	8.663e-01
3	.84	1.751e+13	6.519e-21	4.706e-01
4	.66	1.143e+15	6.223e-21	2.933e+01
5	.48	9.308e+11	5.417e-21	2.079e-02
6	.40	1.997e+11	4.500e-21	3.705e-03
7	.24	6.296e+12	3.557e-21	9.235e-02
8	.20	2.166e+11	2.873e-21	2.566e-03
9	.12	3.859e+13	8.930e-22	1.421e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

TOTALS: 1.272e+15 3.225e+01

RESULTS FOR SENSITIVITY ITERATION 13 OF 15 (DIMENSION X = 18):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	8.091e-21	1.274e+00
2	1.01	2.757e+13	7.322e-21	8.324e-01
3	.84	1.751e+13	6.265e-21	4.523e-01
4	.66	1.143e+15	5.981e-21	2.819e+01
5	.48	9.308e+11	5.207e-21	1.998e-02
6	.40	1.997e+11	4.325e-21	3.561e-03
7	.24	6.296e+12	3.407e-21	8.845e-02
8	.20	2.166e+11	2.749e-21	2.455e-03
9	.12	3.859e+13	8.536e-22	1.358e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		3.100e+01

RESULTS FOR SENSITIVITY ITERATION 14 OF 15 (DIMENSION X = 19):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	7.782e-21	1.225e+00
2	1.01	2.757e+13	7.045e-21	8.009e-01
3	.84	1.751e+13	6.028e-21	4.352e-01
4	.66	1.143e+15	5.756e-21	2.713e+01
5	.48	9.308e+11	5.010e-21	1.923e-02
6	.40	1.997e+11	4.162e-21	3.427e-03
7	.24	6.296e+12	3.267e-21	8.480e-02
8	.20	2.166e+11	2.633e-21	2.352e-03
9	.12	3.859e+13	8.168e-22	1.300e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		2.983e+01

RESULTS FOR SENSITIVITY ITERATION 15 OF 15 (DIMENSION X = 20):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	7.494e-21	1.180e+00
2	1.01	2.757e+13	6.787e-21	7.715e-01
3	.84	1.751e+13	5.808e-21	4.193e-01
4	.66	1.143e+15	5.545e-21	2.613e+01
5	.48	9.308e+11	4.826e-21	1.852e-02
6	.40	1.997e+11	4.008e-21	3.301e-03
7	.24	6.296e+12	3.135e-21	8.139e-02
8	.20	2.166e+11	2.524e-21	2.255e-03
9	.12	3.859e+13	7.823e-22	1.245e-01
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		2.873e+01

MicroSkyshine

(Nuclear & Radiological Safety Analysis - 1.16-007)
 Page: 1
 File: CS6SENBK.SKY
 Run: 10:12 a.m.
 : May 25, 1996

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

CASE: SKYSHINE @ 5M FROM MIDPOINT OF PIPE CENTERLINE - BREMSSTRA

GEOMETRY: Horizontal cylinder source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	5.
Depth of source behind wall.....	Y	1.01
Offset of detector.....	Z	-15.085
Depth of dose point.....	H	-0.5
Distance between source and wall.....	R1	0.01
Distance between near source edge and wall...	R2	1.6952
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	0.8476
Length of source.....	L	30.17

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Length Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

CASE: SKYSHINE @ 5M FROM MIDPOINT OF PIPE CENTERLINE - BREMSSTRA

SOURCE NUCLIDES:

Nuclide	Curies	Nuclide	Curies
Ba-137m	2.7100e+04	Cs-137	2.8647e+04
Eu-154	2.5778e+03		

RESULTS OF SENSITIVITY STUDY ON DIMENSION X - REFERENCE CASE:

Reference case value: 5

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.981e-20	2.777e-06
2	2.10	6.300e+09	1.966e-20	5.106e-04
3	1.90	6.000e+10	1.885e-20	4.665e-03
4	1.70	2.400e+11	1.747e-20	1.729e-02
5	1.48	9.800e+11	1.579e-20	6.381e-02
6	1.23	2.800e+12	1.676e-20	1.935e-01
7	1.00	5.100e+12	1.488e-20	3.128e-01
8	.82	7.200e+12	1.241e-20	3.683e-01
9	.65	1.900e+13	1.190e-20	9.326e-01
10	.47	3.100e+13	1.009e-20	1.290e+00
11	.35	4.000e+13	7.261e-21	1.198e+00
12	.25	7.700e+13	6.972e-21	2.214e+00
13	.15	2.000e+14	3.652e-21	3.012e+00
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		9.607e+00

RESULTS FOR SENSITIVITY ITERATION 1 OF 16 (DIMENSION X = 5):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.981e-20	2.777e-06
2	2.10	6.300e+09	1.966e-20	5.106e-04
3	1.90	6.000e+10	1.885e-20	4.665e-03
4	1.70	2.400e+11	1.747e-20	1.729e-02
5	1.48	9.800e+11	1.579e-20	6.381e-02
6	1.23	2.800e+12	1.676e-20	1.935e-01
7	1.00	5.100e+12	1.488e-20	3.128e-01
8	.82	7.200e+12	1.241e-20	3.683e-01
9	.65	1.900e+13	1.190e-20	9.326e-01
10	.47	3.100e+13	1.009e-20	1.290e+00
11	.35	4.000e+13	7.261e-21	1.198e+00
12	.25	7.700e+13	6.972e-21	2.214e+00
13	.15	2.000e+14	3.652e-21	3.012e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 9.607e+00

RESULTS FOR SENSITIVITY ITERATION 2 OF 16 (DIMENSION X = 6):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.800e-20	2.523e-06
2	2.10	6.300e+09	1.790e-20	4.649e-04
3	1.90	6.000e+10	1.720e-20	4.254e-03
4	1.70	2.400e+11	1.595e-20	1.579e-02
5	1.48	9.800e+11	1.445e-20	5.839e-02
6	1.23	2.800e+12	1.542e-20	1.780e-01
7	1.00	5.100e+12	1.372e-20	2.884e-01
8	.82	7.200e+12	1.146e-20	3.402e-01
9	.65	1.900e+13	1.104e-20	8.651e-01
10	.47	3.100e+13	9.392e-21	1.201e+00
11	.35	4.000e+13	6.771e-21	1.117e+00
12	.25	7.700e+13	6.501e-21	2.064e+00
13	.15	2.000e+14	3.405e-21	2.808e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 8.940e+00

RESULTS FOR SENSITIVITY ITERATION 3 OF 16 (DIMENSION X = 7):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.654e-20	2.319e-06
2	2.10	6.300e+09	1.648e-20	4.280e-04
3	1.90	6.000e+10	1.585e-20	3.921e-03
4	1.70	2.400e+11	1.472e-20	1.457e-02
5	1.48	9.800e+11	1.336e-20	5.397e-02
6	1.23	2.800e+12	1.430e-20	1.651e-01
7	1.00	5.100e+12	1.275e-20	2.682e-01
8	.82	7.200e+12	1.067e-20	3.166e-01
9	.65	1.900e+13	1.031e-20	8.080e-01
10	.47	3.100e+13	8.796e-21	1.124e+00
11	.35	4.000e+13	6.348e-21	1.047e+00
12	.25	7.700e+13	6.088e-21	1.933e+00
13	.15	2.000e+14	3.188e-21	2.629e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 8.364e+00

RESULTS FOR SENSITIVITY ITERATION 4 OF 16 (DIMENSION X = 8):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.532e-20	2.148e-06
2	2.10	6.300e+09	1.528e-20	3.970e-04
3	1.90	6.000e+10	1.472e-20	3.641e-03
4	1.70	2.400e+11	1.368e-20	1.354e-02
5	1.48	9.800e+11	1.243e-20	5.023e-02
6	1.23	2.800e+12	1.335e-20	1.542e-01
7	1.00	5.100e+12	1.193e-20	2.508e-01
8	.82	7.200e+12	9.984e-21	2.964e-01
9	.65	1.900e+13	9.680e-21	7.584e-01
10	.47	3.100e+13	8.273e-21	1.058e+00
11	.35	4.000e+13	5.976e-21	9.857e-01
12	.25	7.700e+13	5.723e-21	1.817e+00
13	.15	2.000e+14	2.993e-21	2.469e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 7.857e+00

RESULTS FOR SENSITIVITY ITERATION 5 OF 16 (DIMENSION X = 9):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.429e-20	2.003e-06
2	2.10	6.300e+09	1.426e-20	3.705e-04
3	1.90	6.000e+10	1.375e-20	3.401e-03
4	1.70	2.400e+11	1.279e-20	1.266e-02
5	1.48	9.800e+11	1.163e-20	4.701e-02
6	1.23	2.800e+12	1.253e-20	1.447e-01
7	1.00	5.100e+12	1.121e-20	2.357e-01
8	.82	7.200e+12	9.389e-21	2.788e-01
9	.65	1.900e+13	9.123e-21	7.148e-01
10	.47	3.100e+13	7.810e-21	9.983e-01
11	.35	4.000e+13	5.646e-21	9.312e-01
12	.25	7.700e+13	5.395e-21	1.713e+00
13	.15	2.000e+14	2.819e-21	2.325e+00
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		7.405e+00

RESULTS FOR SENSITIVITY ITERATION 6 OF 16 (DIMENSION X = 10):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.339e-20	1.877e-06
2	2.10	6.300e+09	1.338e-20	3.476e-04
3	1.90	6.000e+10	1.291e-20	3.193e-03
4	1.70	2.400e+11	1.202e-20	1.189e-02
5	1.48	9.800e+11	1.094e-20	4.421e-02
6	1.23	2.800e+12	1.181e-20	1.363e-01
7	1.00	5.100e+12	1.057e-20	2.223e-01
8	.82	7.200e+12	8.865e-21	2.632e-01
9	.65	1.900e+13	8.628e-21	6.760e-01
10	.47	3.100e+13	7.396e-21	9.454e-01
11	.35	4.000e+13	5.349e-21	8.823e-01
12	.25	7.700e+13	5.100e-21	1.619e+00
13	.15	2.000e+14	2.662e-21	2.195e+00
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		6.999e+00

RESULTS FOR SENSITIVITY ITERATION 7 OF 16 (DIMENSION X = 11):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.261e-20	1.768e-06
2	2.10	6.300e+09	1.261e-20	3.275e-04
3	1.90	6.000e+10	1.217e-20	3.011e-03
4	1.70	2.400e+11	1.134e-20	1.122e-02
5	1.48	9.800e+11	1.033e-20	4.173e-02
6	1.23	2.800e+12	1.117e-20	1.289e-01
7	1.00	5.100e+12	1.001e-20	2.105e-01
8	.82	7.200e+12	8.397e-21	2.493e-01
9	.65	1.900e+13	8.184e-21	6.411e-01
10	.47	3.100e+13	7.022e-21	8.976e-01
11	.35	4.000e+13	5.081e-21	8.381e-01
12	.25	7.700e+13	4.832e-21	1.534e+00
13	.15	2.000e+14	2.518e-21	2.077e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 6.633e+00

RESULTS FOR SENSITIVITY ITERATION 8 OF 16 (DIMENSION X = 12):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.192e-20	1.671e-06
2	2.10	6.300e+09	1.192e-20	3.098e-04
3	1.90	6.000e+10	1.152e-20	2.849e-03
4	1.70	2.400e+11	1.073e-20	1.062e-02
5	1.48	9.800e+11	9.783e-21	3.953e-02
6	1.23	2.800e+12	1.060e-20	1.223e-01
7	1.00	5.100e+12	9.505e-21	1.999e-01
8	.82	7.200e+12	7.977e-21	2.368e-01
9	.65	1.900e+13	7.782e-21	6.097e-01
10	.47	3.100e+13	6.683e-21	8.543e-01
11	.35	4.000e+13	4.838e-21	7.979e-01
12	.25	7.700e+13	4.587e-21	1.456e+00
13	.15	2.000e+14	2.387e-21	1.969e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 6.299e+00

RESULTS FOR SENSITIVITY ITERATION 9 OF 16 (DIMENSION X = 13):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.130e-20	1.584e-06
2	2.10	6.300e+09	1.131e-20	2.939e-04
3	1.90	6.000e+10	1.093e-20	2.704e-03
4	1.70	2.400e+11	1.019e-20	1.009e-02
5	1.48	9.800e+11	9.295e-21	3.756e-02
6	1.23	2.800e+12	1.008e-20	1.164e-01
7	1.00	5.100e+12	9.049e-21	1.903e-01
8	.82	7.200e+12	7.598e-21	2.256e-01
9	.65	1.900e+13	7.418e-21	5.812e-01
10	.47	3.100e+13	6.374e-21	8.147e-01
11	.35	4.000e+13	4.615e-21	7.612e-01
12	.25	7.700e+13	4.363e-21	1.385e+00
13	.15	2.000e+14	2.267e-21	1.870e+00
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		5.995e+00

RESULTS FOR SENSITIVITY ITERATION 10 OF 16 (DIMENSION X = 14):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.075e-20	1.507e-06
2	2.10	6.300e+09	1.076e-20	2.796e-04
3	1.90	6.000e+10	1.040e-20	2.574e-03
4	1.70	2.400e+11	9.703e-21	9.603e-03
5	1.48	9.800e+11	8.855e-21	3.578e-02
6	1.23	2.800e+12	9.613e-21	1.110e-01
7	1.00	5.100e+12	8.634e-21	1.816e-01
8	.82	7.200e+12	7.252e-21	2.153e-01
9	.65	1.900e+13	7.085e-21	5.551e-01
10	.47	3.100e+13	6.090e-21	7.785e-01
11	.35	4.000e+13	4.410e-21	7.274e-01
12	.25	7.700e+13	4.157e-21	1.320e+00
13	.15	2.000e+14	2.156e-21	1.778e+00
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		5.715e+00

RESULTS FOR SENSITIVITY ITERATION 11 OF 16 (DIMENSION X = 15):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.024e-20	1.436e-06
2	2.10	6.300e+09	1.027e-20	2.667e-04
3	1.90	6.000e+10	9.926e-21	2.456e-03
4	1.70	2.400e+11	9.261e-21	9.165e-03
5	1.48	9.800e+11	8.454e-21	3.416e-02
6	1.23	2.800e+12	9.187e-21	1.061e-01
7	1.00	5.100e+12	8.256e-21	1.736e-01
8	.82	7.200e+12	6.937e-21	2.059e-01
9	.65	1.900e+13	6.780e-21	5.312e-01
10	.47	3.100e+13	5.829e-21	7.451e-01
11	.35	4.000e+13	4.222e-21	6.964e-01
12	.25	7.700e+13	3.967e-21	1.260e+00
13	.15	2.000e+14	2.054e-21	1.694e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 5.458e+00

RESULTS FOR SENSITIVITY ITERATION 12 OF 16 (DIMENSION X = 16):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	9.789e-21	1.372e-06
2	2.10	6.300e+09	9.812e-21	2.549e-04
3	1.90	6.000e+10	9.490e-21	2.348e-03
4	1.70	2.400e+11	8.856e-21	8.765e-03
5	1.48	9.800e+11	8.088e-21	3.268e-02
6	1.23	2.800e+12	8.797e-21	1.016e-01
7	1.00	5.100e+12	7.909e-21	1.663e-01
8	.82	7.200e+12	6.647e-21	1.973e-01
9	.65	1.900e+13	6.498e-21	5.091e-01
10	.47	3.100e+13	5.588e-21	7.143e-01
11	.35	4.000e+13	4.048e-21	6.676e-01
12	.25	7.700e+13	3.791e-21	1.204e+00
13	.15	2.000e+14	1.960e-21	1.616e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 5.220e+00

RESULTS FOR SENSITIVITY ITERATION 13 OF 16 (DIMENSION X = 17):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	9.371e-21	1.314e-06
2	2.10	6.300e+09	9.396e-21	2.441e-04
3	1.90	6.000e+10	9.090e-21	2.249e-03
4	1.70	2.400e+11	8.485e-21	8.397e-03
5	1.48	9.800e+11	7.752e-21	3.133e-02
6	1.23	2.800e+12	8.437e-21	9.741e-02
7	1.00	5.100e+12	7.588e-21	1.596e-01
8	.82	7.200e+12	6.379e-21	1.894e-01
9	.65	1.900e+13	6.237e-21	4.886e-01
10	.47	3.100e+13	5.364e-21	6.857e-01
11	.35	4.000e+13	3.885e-21	6.409e-01
12	.25	7.700e+13	3.627e-21	1.152e+00
13	.15	2.000e+14	1.872e-21	1.543e+00
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		4.999e+00

RESULTS FOR SENSITIVITY ITERATION 14 OF 16 (DIMENSION X = 18):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	8.986e-21	1.260e-06
2	2.10	6.300e+09	9.013e-21	2.341e-04
3	1.90	6.000e+10	8.722e-21	2.158e-03
4	1.70	2.400e+11	8.143e-21	8.058e-03
5	1.48	9.800e+11	7.441e-21	3.007e-02
6	1.23	2.800e+12	8.104e-21	9.356e-02
7	1.00	5.100e+12	7.291e-21	1.533e-01
8	.82	7.200e+12	6.130e-21	1.820e-01
9	.65	1.900e+13	5.994e-21	4.696e-01
10	.47	3.100e+13	5.156e-21	6.590e-01
11	.35	4.000e+13	3.734e-21	6.159e-01
12	.25	7.700e+13	3.475e-21	1.103e+00
13	.15	2.000e+14	1.790e-21	1.476e+00
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		4.793e+00

RESULTS FOR SENSITIVITY ITERATION 15 OF 16 (DIMENSION X = 19):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	8.631e-21	1.210e-06
2	2.10	6.300e+09	8.660e-21	2.250e-04
3	1.90	6.000e+10	8.381e-21	2.074e-03
4	1.70	2.400e+11	7.826e-21	7.745e-03
5	1.48	9.800e+11	7.154e-21	2.891e-02
6	1.23	2.800e+12	7.795e-21	8.999e-02
7	1.00	5.100e+12	7.015e-21	1.475e-01
8	.82	7.200e+12	5.899e-21	1.751e-01
9	.65	1.900e+13	5.768e-21	4.519e-01
10	.47	3.100e+13	4.961e-21	6.341e-01
11	.35	4.000e+13	3.593e-21	5.927e-01
12	.25	7.700e+13	3.332e-21	1.058e+00
13	.15	2.000e+14	1.713e-21	1.413e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 4.601e+00

RESULTS FOR SENSITIVITY ITERATION 16 OF 16 (DIMENSION X = 20):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	8.303e-21	1.164e-06
2	2.10	6.300e+09	8.332e-21	2.164e-04
3	1.90	6.000e+10	8.065e-21	1.995e-03
4	1.70	2.400e+11	7.533e-21	7.454e-03
5	1.48	9.800e+11	6.887e-21	2.783e-02
6	1.23	2.800e+12	7.507e-21	8.667e-02
7	1.00	5.100e+12	6.758e-21	1.421e-01
8	.82	7.200e+12	5.683e-21	1.687e-01
9	.65	1.900e+13	5.557e-21	4.354e-01
10	.47	3.100e+13	4.778e-21	6.108e-01
11	.35	4.000e+13	3.461e-21	5.708e-01
12	.25	7.700e+13	3.199e-21	1.016e+00
13	.15	2.000e+14	1.641e-21	1.354e+00
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 4.421e+00

MicroSkyshine

=====

(Nuclear & Radiological Safety Analysis - 1.16-007)
 Page: 1 File Ref: _____
 File: CASE6100.SKY Date: / /
 Run: 6:23 a.m. By: _____
 : May 31, 1996 Checked: _____

CASE: SKYSHINE @ 100M FROM MIDPOINT OF PIPE CENTERLINE

GEOMETRY: Horizontal cylinder source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	100.
Depth of source behind wall.....	Y	1.01
Offset of detector.....	Z	-15.085
Depth of dose point.....	H	-0.5
Distance between source and wall.....	R1	0.01
Distance between near source edge and wall...	R2	1.6952
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	0.8476
Length of source.....	L	30.17

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Length Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
-----	-----	-----	-----
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

CASE: SKYSHINE @ 100M FROM MIDPOINT OF PIPE CENTERLINE

SOURCE NUCLIDES:

Nuclide	Curies	Nuclide	Curies
Ba-137m	3.3491e+04	Cs-137	3.5403e+04
Eu-154	2.5773e+03		

RESULTS:

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.338e-21	2.107e-01
2	1.01	2.757e+13	1.186e-21	1.348e-01
3	.84	1.751e+13	1.007e-21	7.271e-02
4	.66	1.143e+15	9.118e-22	4.297e+00
5	.48	9.308e+11	7.496e-22	2.877e-03
6	.40	1.997e+11	6.129e-22	5.047e-04
7	.24	6.296e+12	3.686e-22	9.569e-03
8	.20	2.166e+11	2.737e-22	2.445e-04
9	.12	3.859e+13	7.719e-23	1.228e-02
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.741e+00

MicroSkyshine

=====

(Nuclear & Radiological Safety Analysis - 1.16-007)
 Page: 1
 File: CS6100BR.SKY
 Run: 10:12 a.m.
 : May 25, 1996

File Ref: _____
 Date: _____
 By: _____
 Checked: _____

CASE: SKYSHINE @ 100M FROM MIDPOINT OF PIPE CENTERLINE - BREMSSTRA

GEOMETRY: Horizontal cylinder source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	100.
Depth of source behind wall.....	Y	1.01
Offset of detector.....	Z	-15.085
Depth of dose point.....	H	-0.5
Distance between source and wall.....	R1	0.01
Distance between near source edge and wall...	R2	1.6952
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	0.8476
Length of source.....	L	30.17

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Length Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
-----	-----	-----	-----
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

CASE: SKYSHINE @ 100M FROM MIDPOINT OF PIPE CENTERLINE - BREMSSTRA

SOURCE NUCLIDES:

Nuclide	Curies	Nuclide	Curies
Ba-137m	2.7100e+04	Cs-137	2.8647e+04
Eu-154	2.5778e+03		

RESULTS:

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.550e-21	2.172e-07
2	2.10	6.300e+09	1.546e-21	4.015e-05
3	1.90	6.000e+10	1.489e-21	3.685e-04
4	1.70	2.400e+11	1.386e-21	1.372e-03
5	1.48	9.800e+11	1.258e-21	5.084e-03
6	1.23	2.800e+12	1.331e-21	1.537e-02
7	1.00	5.100e+12	1.181e-21	2.483e-02
8	.82	7.200e+12	9.848e-22	2.924e-02
9	.65	1.900e+13	9.079e-22	7.113e-02
10	.47	3.100e+13	7.413e-22	9.475e-02
11	.35	4.000e+13	5.251e-22	8.661e-02
12	.25	7.700e+13	3.823e-22	1.214e-01
13	.15	2.000e+14	1.678e-22	1.384e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		5.886e-01

MicroSkyshine

=====

(Nuclear & Radiological Safety Analysis - 1.16-007)
 Page: 1 File Ref: _____
 File: CASE7SEN.SKY Date: ___/___/___
 Run: 6:23 a.m. By: _____
 : May 31, 1996 Checked: _____

CASE: Vertical Cylinder - Skyshine @ 5 m

GEOMETRY: Vertical cylinder area source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	5.
Depth of source behind wall.....	Y	0.16
Offset of detector.....	Z	0.
Depth of dose point.....	H	-0.1
Distance between center of source and wall...	R1	0.01
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	3.575
Height of source.....	L	1.6952

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Vertical Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

CASE: Vertical Cylinder - Skyshine @ 5 m

SOURCE NUCLIDES:

Nuclide	Curies	Nuclide	Curies
Ba-137m	3.3491e+04	Cs-137	3.5403e+04
Eu-154	2.5773e+03		

RESULTS OF SENSITIVITY STUDY ON DIMENSION X - REFERENCE CASE:

Reference case value: 5

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	4.083e-21	6.430e-01
2	1.01	2.757e+13	3.250e-21	3.694e-01
3	.84	1.751e+13	2.544e-21	1.837e-01
4	.66	1.143e+15	2.167e-21	1.021e+01
5	.48	9.308e+11	1.593e-21	6.115e-03
6	.40	1.997e+11	1.192e-21	9.815e-04
7	.24	6.296e+12	7.730e-22	2.007e-02
8	.20	2.166e+11	5.516e-22	4.927e-04
9	.12	3.859e+13	1.026e-22	1.632e-02
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		1.145e+01

RESULTS FOR SENSITIVITY ITERATION 1 OF 15 (DIMENSION X = 6):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	3.513e-21	5.533e-01
2	1.01	2.757e+13	2.809e-21	3.194e-01
3	.84	1.751e+13	2.203e-21	1.591e-01
4	.66	1.143e+15	1.886e-21	8.887e+00
5	.48	9.308e+11	1.393e-21	5.345e-03
6	.40	1.997e+11	1.043e-21	8.587e-04
7	.24	6.296e+12	6.733e-22	1.748e-02
8	.20	2.166e+11	4.798e-22	4.286e-04
9	.12	3.859e+13	8.911e-23	1.418e-02
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		9.956e+00

RESULTS FOR SENSITIVITY ITERATION 2 OF 15 (DIMENSION X = 7):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	3.107e-21	4.892e-01
2	1.01	2.757e+13	2.492e-21	2.833e-01
3	.84	1.751e+13	1.957e-21	1.413e-01
4	.66	1.143e+15	1.680e-21	7.915e+00
5	.48	9.308e+11	1.243e-21	4.772e-03
6	.40	1.997e+11	9.317e-22	7.672e-04
7	.24	6.296e+12	5.981e-22	1.553e-02
8	.20	2.166e+11	4.255e-22	3.801e-04
9	.12	3.859e+13	7.890e-23	1.255e-02
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		8.863e+00

Page 4

RESULTS FOR SENSITIVITY ITERATION 3 OF 15 (DIMENSION X = 8):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	2.799e-21	4.408e-01
2	1.01	2.757e+13	2.251e-21	2.559e-01
3	.84	1.751e+13	1.769e-21	1.277e-01
4	.66	1.143e+15	1.521e-21	7.168e+00
5	.48	9.308e+11	1.128e-21	4.328e-03
6	.40	1.997e+11	8.452e-22	6.959e-04
7	.24	6.296e+12	5.391e-22	1.400e-02
8	.20	2.166e+11	3.830e-22	3.421e-04
9	.12	3.859e+13	7.089e-23	1.128e-02
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		8.023e+00

RESULTS FOR SENSITIVITY ITERATION 4 OF 15 (DIMENSION X = 9):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	2.557e-21	4.027e-01
2	1.01	2.757e+13	2.060e-21	2.341e-01
3	.84	1.751e+13	1.619e-21	1.169e-01
4	.66	1.143e+15	1.394e-21	6.570e+00
5	.48	9.308e+11	1.034e-21	3.969e-03
6	.40	1.997e+11	7.753e-22	6.384e-04
7	.24	6.296e+12	4.915e-22	1.276e-02
8	.20	2.166e+11	3.486e-22	3.114e-04
9	.12	3.859e+13	6.440e-23	1.025e-02
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		7.351e+00

Page 5

RESULTS FOR SENSITIVITY ITERATION 5 OF 15 (DIMENSION X = 10):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	2.360e-21	3.716e-01
2	1.01	2.757e+13	1.903e-21	2.163e-01
3	.84	1.751e+13	1.497e-21	1.081e-01
4	.66	1.143e+15	1.289e-21	6.077e+00
5	.48	9.308e+11	9.569e-22	3.673e-03
6	.40	1.997e+11	7.174e-22	5.908e-04
7	.24	6.296e+12	4.519e-22	1.173e-02
8	.20	2.166e+11	3.200e-22	2.859e-04
9	.12	3.859e+13	5.903e-23	9.392e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		6.798e+00

RESULTS FOR SENSITIVITY ITERATION 6 OF 15 (DIMENSION X = 11):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	2.194e-21	3.456e-01
2	1.01	2.757e+13	1.772e-21	2.014e-01
3	.84	1.751e+13	1.394e-21	1.006e-01
4	.66	1.143e+15	1.201e-21	5.661e+00
5	.48	9.308e+11	8.916e-22	3.422e-03
6	.40	1.997e+11	6.684e-22	5.504e-04
7	.24	6.296e+12	4.185e-22	1.086e-02
8	.20	2.166e+11	2.959e-22	2.643e-04
9	.12	3.859e+13	5.448e-23	8.668e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		6.332e+00

Page 6

RESULTS FOR SENSITIVITY ITERATION 7 OF 15 (DIMENSION X = 12):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	2.054e-21	3.234e-01
2	1.01	2.757e+13	1.659e-21	1.886e-01
3	.84	1.751e+13	1.306e-21	9.429e-02
4	.66	1.143e+15	1.125e-21	5.304e+00
5	.48	9.308e+11	8.352e-22	3.206e-03
6	.40	1.997e+11	6.261e-22	5.156e-04
7	.24	6.296e+12	3.897e-22	1.012e-02
8	.20	2.166e+11	2.751e-22	2.457e-04
9	.12	3.859e+13	5.057e-23	8.046e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		5.932e+00

RESULTS FOR SENSITIVITY ITERATION 8 OF 15 (DIMENSION X = 13):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.932e-21	3.042e-01
2	1.01	2.757e+13	1.562e-21	1.775e-01
3	.84	1.751e+13	1.230e-21	8.877e-02
4	.66	1.143e+15	1.059e-21	4.993e+00
5	.48	9.308e+11	7.861e-22	3.017e-03
6	.40	1.997e+11	5.892e-22	4.852e-04
7	.24	6.296e+12	3.646e-22	9.464e-03
8	.20	2.166e+11	2.570e-22	2.296e-04
9	.12	3.859e+13	4.717e-23	7.505e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		5.584e+00

Page 7

RESULTS FOR SENSITIVITY ITERATION 9 OF 15 (DIMENSION X = 14):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.825e-21	2.873e-01
2	1.01	2.757e+13	1.476e-21	1.678e-01
3	.84	1.751e+13	1.162e-21	8.391e-02
4	.66	1.143e+15	1.001e-21	4.719e+00
5	.48	9.308e+11	7.426e-22	2.850e-03
6	.40	1.997e+11	5.566e-22	4.583e-04
7	.24	6.296e+12	3.424e-22	8.890e-03
8	.20	2.166e+11	2.411e-22	2.153e-04
9	.12	3.859e+13	4.417e-23	7.028e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		5.277e+00

RESULTS FOR SENSITIVITY ITERATION 10 OF 15 (DIMENSION X = 15):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.730e-21	2.724e-01
2	1.01	2.757e+13	1.400e-21	1.591e-01
3	.84	1.751e+13	1.102e-21	7.959e-02
4	.66	1.143e+15	9.494e-22	4.474e+00
5	.48	9.308e+11	7.039e-22	2.702e-03
6	.40	1.997e+11	5.275e-22	4.344e-04
7	.24	6.296e+12	3.227e-22	8.378e-03
8	.20	2.166e+11	2.269e-22	2.026e-04
9	.12	3.859e+13	4.151e-23	6.604e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		5.004e+00

RESULTS FOR SENSITIVITY ITERATION 11 OF 15 (DIMENSION X = 16):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.645e-21	2.590e-01
2	1.01	2.757e+13	1.331e-21	1.514e-01
3	.84	1.751e+13	1.049e-21	7.571e-02
4	.66	1.143e+15	9.029e-22	4.255e+00
5	.48	9.308e+11	6.691e-22	2.568e-03
6	.40	1.997e+11	5.013e-22	4.128e-04
7	.24	6.296e+12	3.051e-22	7.919e-03
8	.20	2.166e+11	2.141e-22	1.913e-04
9	.12	3.859e+13	3.912e-23	6.225e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.758e+00

RESULTS FOR SENSITIVITY ITERATION 12 OF 15 (DIMENSION X = 17):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.568e-21	2.469e-01
2	1.01	2.757e+13	1.270e-21	1.443e-01
3	.84	1.751e+13	1.000e-21	7.221e-02
4	.66	1.143e+15	8.607e-22	4.056e+00
5	.48	9.308e+11	6.375e-22	2.447e-03
6	.40	1.997e+11	4.776e-22	3.933e-04
7	.24	6.296e+12	2.891e-22	7.505e-03
8	.20	2.166e+11	2.027e-22	1.810e-04
9	.12	3.859e+13	3.697e-23	5.882e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.536e+00

RESULTS FOR SENSITIVITY ITERATION 13 OF 15 (DIMENSION X = 18):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.498e-21	2.360e-01
2	1.01	2.757e+13	1.214e-21	1.380e-01
3	.84	1.751e+13	9.561e-22	6.902e-02
4	.66	1.143e+15	8.224e-22	3.876e+00
5	.48	9.308e+11	6.088e-22	2.337e-03
6	.40	1.997e+11	4.560e-22	3.755e-04
7	.24	6.296e+12	2.746e-22	7.128e-03
8	.20	2.166e+11	1.922e-22	1.717e-04
9	.12	3.859e+13	3.502e-23	5.571e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.334e+00

RESULTS FOR SENSITIVITY ITERATION 14 OF 15 (DIMENSION X = 19):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.435e-21	2.259e-01
2	1.01	2.757e+13	1.162e-21	1.321e-01
3	.84	1.751e+13	9.157e-22	6.611e-02
4	.66	1.143e+15	7.872e-22	3.710e+00
5	.48	9.308e+11	5.824e-22	2.235e-03
6	.40	1.997e+11	4.362e-22	3.592e-04
7	.24	6.296e+12	2.613e-22	6.784e-03
8	.20	2.166e+11	1.827e-22	1.632e-04
9	.12	3.859e+13	3.323e-23	5.288e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		4.149e+00

RESULTS FOR SENSITIVITY ITERATION 15 OF 15 (DIMENSION X = 20):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	1.376e-21	2.168e-01
2	1.01	2.757e+13	1.115e-21	1.268e-01
3	.84	1.751e+13	8.786e-22	6.343e-02
4	.66	1.143e+15	7.549e-22	3.558e+00
5	.48	9.308e+11	5.582e-22	2.142e-03
6	.40	1.997e+11	4.179e-22	3.442e-04
7	.24	6.296e+12	2.491e-22	6.467e-03
8	.20	2.166e+11	1.740e-22	1.554e-04
9	.12	3.859e+13	3.160e-23	5.028e-03
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		3.979e+00

MicroSkyshine

(Nuclear & Radiological Safety Analysis - 1.16-007)

Page: 1
 File: CS7SENBR.SKY
 Run: 7:25 a.m.
 : May 28, 1996

File Ref: _____
 Date: ____/____/____
 By: _____
 Checked: _____

CASE: Vertical Cylinder - Skyshine @ 5 m - Bremsstrahlung

GEOMETRY: Vertical cylinder area source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	5.
Depth of source behind wall.....	Y	0.16
Offset of detector.....	Z	0.
Depth of dose point.....	H	-0.1
Distance between center of source and wall...	R1	0.01
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	3.575
Height of source.....	L	1.6952

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Vertical Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

CASE: Vertical Cylinder - Skyshine @ 5 m - Bremsstrahlung

SOURCE NUCLIDES:

Source was entered by energy groups.

RESULTS OF SENSITIVITY STUDY ON DIMENSION X - REFERENCE CASE:

Reference case value: 5

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	5.910e-21	8.286e-07
2	2.10	6.300e+09	5.685e-21	1.477e-04
3	1.90	6.000e+10	5.260e-21	1.301e-03
4	1.70	2.400e+11	4.672e-21	4.624e-03
5	1.48	9.800e+11	3.995e-21	1.614e-02
6	1.23	2.800e+12	3.974e-21	4.589e-02
7	1.00	5.100e+12	3.227e-21	6.787e-02
8	.82	7.200e+12	2.463e-21	7.313e-02
9	.65	1.900e+13	2.147e-21	1.682e-01
10	.47	3.100e+13	1.567e-21	2.003e-01
11	.35	4.000e+13	9.553e-22	1.576e-01
12	.25	7.700e+13	8.002e-22	2.541e-01
13	.15	2.000e+14	2.934e-22	2.420e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		1.231e+00

RESULTS FOR SENSITIVITY ITERATION 1 OF 16 (DIMENSION X = 5):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	5.910e-21	8.286e-07
2	2.10	6.300e+09	5.685e-21	1.477e-04
3	1.90	6.000e+10	5.260e-21	1.301e-03
4	1.70	2.400e+11	4.672e-21	4.624e-03
5	1.48	9.800e+11	3.995e-21	1.614e-02
6	1.23	2.800e+12	3.974e-21	4.589e-02
7	1.00	5.100e+12	3.227e-21	6.787e-02
8	.82	7.200e+12	2.463e-21	7.313e-02
9	.65	1.900e+13	2.147e-21	1.682e-01
10	.47	3.100e+13	1.567e-21	2.003e-01
11	.35	4.000e+13	9.553e-22	1.576e-01
12	.25	7.700e+13	8.002e-22	2.541e-01
13	.15	2.000e+14	2.934e-22	2.420e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		1.231e+00

RESULTS FOR SENSITIVITY ITERATION 2 OF 16 (DIMENSION X = 6):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	4.999e-21	7.008e-07
2	2.10	6.300e+09	4.825e-21	1.253e-04
3	1.90	6.000e+10	4.478e-21	1.108e-03
4	1.70	2.400e+11	3.987e-21	3.946e-03
5	1.48	9.800e+11	3.421e-21	1.382e-02
6	1.23	2.800e+12	3.425e-21	3.954e-02
7	1.00	5.100e+12	2.790e-21	5.868e-02
8	.82	7.200e+12	2.134e-21	6.334e-02
9	.65	1.900e+13	1.870e-21	1.465e-01
10	.47	3.100e+13	1.370e-21	1.751e-01
11	.35	4.000e+13	8.363e-22	1.379e-01
12	.25	7.700e+13	6.972e-22	2.214e-01
13	.15	2.000e+14	2.550e-22	2.103e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		1.072e+00

RESULTS FOR SENSITIVITY ITERATION 3 OF 16 (DIMENSION X = 7):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	4.369e-21	6.126e-07
2	2.10	6.300e+09	4.227e-21	1.098e-04
3	1.90	6.000e+10	3.931e-21	9.725e-04
4	1.70	2.400e+11	3.506e-21	3.470e-03
5	1.48	9.800e+11	3.014e-21	1.218e-02
6	1.23	2.800e+12	3.031e-21	3.500e-02
7	1.00	5.100e+12	2.475e-21	5.205e-02
8	.82	7.200e+12	1.895e-21	5.626e-02
9	.65	1.900e+13	1.666e-21	1.305e-01
10	.47	3.100e+13	1.223e-21	1.564e-01
11	.35	4.000e+13	7.473e-22	1.233e-01
12	.25	7.700e+13	6.195e-22	1.967e-01
13	.15	2.000e+14	2.259e-22	1.863e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		9.532e-01

RESULTS FOR SENSITIVITY ITERATION 4 OF 16 (DIMENSION X = 8):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	3.905e-21	5.475e-07
2	2.10	6.300e+09	3.784e-21	9.831e-05
3	1.90	6.000e+10	3.524e-21	8.718e-04
4	1.70	2.400e+11	3.147e-21	3.114e-03
5	1.48	9.800e+11	2.710e-21	1.095e-02
6	1.23	2.800e+12	2.733e-21	3.156e-02
7	1.00	5.100e+12	2.236e-21	4.701e-02
8	.82	7.200e+12	1.713e-21	5.086e-02
9	.65	1.900e+13	1.509e-21	1.182e-01
10	.47	3.100e+13	1.109e-21	1.418e-01
11	.35	4.000e+13	6.780e-22	1.118e-01
12	.25	7.700e+13	5.586e-22	1.774e-01
13	.15	2.000e+14	2.031e-22	1.675e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		8.612e-01

RESULTS FOR SENSITIVITY ITERATION 5 OF 16 (DIMENSION X = 9):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	3.545e-21	4.970e-07
2	2.10	6.300e+09	3.440e-21	8.936e-05
3	1.90	6.000e+10	3.206e-21	7.932e-04
4	1.70	2.400e+11	2.866e-21	2.836e-03
5	1.48	9.800e+11	2.471e-21	9.984e-03
6	1.23	2.800e+12	2.498e-21	2.884e-02
7	1.00	5.100e+12	2.046e-21	4.302e-02
8	.82	7.200e+12	1.569e-21	4.657e-02
9	.65	1.900e+13	1.383e-21	1.084e-01
10	.47	3.100e+13	1.018e-21	1.301e-01
11	.35	4.000e+13	6.220e-22	1.026e-01
12	.25	7.700e+13	5.094e-22	1.617e-01
13	.15	2.000e+14	1.847e-22	1.523e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		7.872e-01

RESULTS FOR SENSITIVITY ITERATION 6 OF 16 (DIMENSION X = 10):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	3.255e-21	4.564e-07
2	2.10	6.300e+09	3.162e-21	8.214e-05
3	1.90	6.000e+10	2.949e-21	7.297e-04
4	1.70	2.400e+11	2.638e-21	2.611e-03
5	1.48	9.800e+11	2.277e-21	9.200e-03
6	1.23	2.800e+12	2.306e-21	2.663e-02
7	1.00	5.100e+12	1.890e-21	3.975e-02
8	.82	7.200e+12	1.450e-21	4.305e-02
9	.65	1.900e+13	1.279e-21	1.002e-01
10	.47	3.100e+13	9.415e-22	1.204e-01
11	.35	4.000e+13	5.756e-22	9.493e-02
12	.25	7.700e+13	4.686e-22	1.488e-01
13	.15	2.000e+14	1.694e-22	1.397e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		7.260e-01

RESULTS FOR SENSITIVITY ITERATION 7 OF 16 (DIMENSION X = 11):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	3.016e-21	4.228e-07
2	2.10	6.300e+09	2.931e-21	7.615e-05
3	1.90	6.000e+10	2.736e-21	6.770e-04
4	1.70	2.400e+11	2.449e-21	2.424e-03
5	1.48	9.800e+11	2.115e-21	8.546e-03
6	1.23	2.800e+12	2.145e-21	2.477e-02
7	1.00	5.100e+12	1.760e-21	3.701e-02
8	.82	7.200e+12	1.350e-21	4.009e-02
9	.65	1.900e+13	1.192e-21	9.338e-02
10	.47	3.100e+13	8.772e-22	1.121e-01
11	.35	4.000e+13	5.362e-22	8.844e-02
12	.25	7.700e+13	4.340e-22	1.378e-01
13	.15	2.000e+14	1.564e-22	1.290e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		6.743e-01

RESULTS FOR SENSITIVITY ITERATION 8 OF 16 (DIMENSION X = 12):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	2.814e-21	3.944e-07
2	2.10	6.300e+09	2.737e-21	7.109e-05
3	1.90	6.000e+10	2.556e-21	6.323e-04
4	1.70	2.400e+11	2.288e-21	2.265e-03
5	1.48	9.800e+11	1.977e-21	7.990e-03
6	1.23	2.800e+12	2.008e-21	2.319e-02
7	1.00	5.100e+12	1.648e-21	3.466e-02
8	.82	7.200e+12	1.265e-21	3.756e-02
9	.65	1.900e+13	1.117e-21	8.749e-02
10	.47	3.100e+13	8.218e-22	1.050e-01
11	.35	4.000e+13	5.023e-22	8.285e-02
12	.25	7.700e+13	4.043e-22	1.284e-01
13	.15	2.000e+14	1.453e-22	1.198e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		6.299e-01

RESULTS FOR SENSITIVITY ITERATION 9 OF 16 (DIMENSION X = 13):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	2.640e-21	3.701e-07
2	2.10	6.300e+09	2.569e-21	6.673e-05
3	1.90	6.000e+10	2.400e-21	5.937e-04
4	1.70	2.400e+11	2.150e-21	2.127e-03
5	1.48	9.800e+11	1.858e-21	7.510e-03
6	1.23	2.800e+12	1.889e-21	2.181e-02
7	1.00	5.100e+12	1.551e-21	3.262e-02
8	.82	7.200e+12	1.191e-21	3.536e-02
9	.65	1.900e+13	1.051e-21	8.236e-02
10	.47	3.100e+13	7.734e-22	9.886e-02
11	.35	4.000e+13	4.727e-22	7.796e-02
12	.25	7.700e+13	3.784e-22	1.201e-01
13	.15	2.000e+14	1.356e-22	1.118e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		5.912e-01

RESULTS FOR SENSITIVITY ITERATION 10 OF 16 (DIMENSION X = 14):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	2.488e-21	3.488e-07
2	2.10	6.300e+09	2.422e-21	6.292e-05
3	1.90	6.000e+10	2.264e-21	5.601e-04
4	1.70	2.400e+11	2.029e-21	2.007e-03
5	1.48	9.800e+11	1.754e-21	7.089e-03
6	1.23	2.800e+12	1.785e-21	2.061e-02
7	1.00	5.100e+12	1.466e-21	3.083e-02
8	.82	7.200e+12	1.126e-21	3.343e-02
9	.65	1.900e+13	9.934e-22	7.783e-02
10	.47	3.100e+13	7.307e-22	9.340e-02
11	.35	4.000e+13	4.465e-22	7.364e-02
12	.25	7.700e+13	3.555e-22	1.129e-01
13	.15	2.000e+14	1.270e-22	1.048e-01
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		5.571e-01

RESULTS FOR SENSITIVITY ITERATION 11 OF 16 (DIMENSION X = 15):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	2.354e-21	3.301e-07
2	2.10	6.300e+09	2.293e-21	5.956e-05
3	1.90	6.000e+10	2.144e-21	5.303e-04
4	1.70	2.400e+11	1.921e-21	1.901e-03
5	1.48	9.800e+11	1.662e-21	6.717e-03
6	1.23	2.800e+12	1.692e-21	1.954e-02
7	1.00	5.100e+12	1.390e-21	2.924e-02
8	.82	7.200e+12	1.068e-21	3.171e-02
9	.65	1.900e+13	9.419e-22	7.380e-02
10	.47	3.100e+13	6.925e-22	8.853e-02
11	.35	4.000e+13	4.231e-22	6.979e-02
12	.25	7.700e+13	3.352e-22	1.064e-01
13	.15	2.000e+14	1.195e-22	9.851e-02
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 5.267e-01

RESULTS FOR SENSITIVITY ITERATION 12 OF 16 (DIMENSION X = 16):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	2.235e-21	3.134e-07
2	2.10	6.300e+09	2.178e-21	5.657e-05
3	1.90	6.000e+10	2.036e-21	5.038e-04
4	1.70	2.400e+11	1.826e-21	1.807e-03
5	1.48	9.800e+11	1.580e-21	6.385e-03
6	1.23	2.800e+12	1.609e-21	1.858e-02
7	1.00	5.100e+12	1.323e-21	2.781e-02
8	.82	7.200e+12	1.016e-21	3.016e-02
9	.65	1.900e+13	8.957e-22	7.018e-02
10	.47	3.100e+13	6.583e-22	8.414e-02
11	.35	4.000e+13	4.021e-22	6.632e-02
12	.25	7.700e+13	3.169e-22	1.006e-01
13	.15	2.000e+14	1.127e-22	9.290e-02
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 4.995e-01

RESULTS FOR SENSITIVITY ITERATION 13 OF 16 (DIMENSION X = 17):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	2.128e-21	2.984e-07
2	2.10	6.300e+09	2.074e-21	5.388e-05
3	1.90	6.000e+10	1.940e-21	4.800e-04
4	1.70	2.400e+11	1.740e-21	1.722e-03
5	1.48	9.800e+11	1.506e-21	6.085e-03
6	1.23	2.800e+12	1.534e-21	1.772e-02
7	1.00	5.100e+12	1.261e-21	2.652e-02
8	.82	7.200e+12	9.690e-22	2.877e-02
9	.65	1.900e+13	8.539e-22	6.690e-02
10	.47	3.100e+13	6.272e-22	8.018e-02
11	.35	4.000e+13	3.830e-22	6.318e-02
12	.25	7.700e+13	3.004e-22	9.538e-02
13	.15	2.000e+14	1.065e-22	8.784e-02
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		4.748e-01

RESULTS FOR SENSITIVITY ITERATION 14 OF 16 (DIMENSION X = 18):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	2.032e-21	2.848e-07
2	2.10	6.300e+09	1.980e-21	5.144e-05
3	1.90	6.000e+10	1.853e-21	4.584e-04
4	1.70	2.400e+11	1.662e-21	1.644e-03
5	1.48	9.800e+11	1.439e-21	5.814e-03
6	1.23	2.800e+12	1.467e-21	1.693e-02
7	1.00	5.100e+12	1.206e-21	2.535e-02
8	.82	7.200e+12	9.263e-22	2.750e-02
9	.65	1.900e+13	8.158e-22	6.391e-02
10	.47	3.100e+13	5.989e-22	7.656e-02
11	.35	4.000e+13	3.657e-22	6.031e-02
12	.25	7.700e+13	2.854e-22	9.061e-02
13	.15	2.000e+14	1.009e-22	8.324e-02
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		4.524e-01

RESULTS FOR SENSITIVITY ITERATION 15 OF 16 (DIMENSION X = 19):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.944e-21	2.725e-07
2	2.10	6.300e+09	1.895e-21	4.923e-05
3	1.90	6.000e+10	1.773e-21	4.387e-04
4	1.70	2.400e+11	1.590e-21	1.574e-03
5	1.48	9.800e+11	1.377e-21	5.566e-03
6	1.23	2.800e+12	1.404e-21	1.621e-02
7	1.00	5.100e+12	1.155e-21	2.428e-02
8	.82	7.200e+12	8.872e-22	2.634e-02
9	.65	1.900e+13	7.809e-22	6.118e-02
10	.47	3.100e+13	5.730e-22	7.324e-02
11	.35	4.000e+13	3.497e-22	5.769e-02
12	.25	7.700e+13	2.717e-22	8.626e-02
13	.15	2.000e+14	9.585e-23	7.905e-02
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 4.319e-01

RESULTS FOR SENSITIVITY ITERATION 16 OF 16 (DIMENSION X = 20):

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	1.863e-21	2.612e-07
2	2.10	6.300e+09	1.817e-21	4.720e-05
3	1.90	6.000e+10	1.700e-21	4.207e-04
4	1.70	2.400e+11	1.525e-21	1.510e-03
5	1.48	9.800e+11	1.321e-21	5.339e-03
6	1.23	2.800e+12	1.347e-21	1.556e-02
7	1.00	5.100e+12	1.108e-21	2.330e-02
8	.82	7.200e+12	8.512e-22	2.527e-02
9	.65	1.900e+13	7.488e-22	5.866e-02
10	.47	3.100e+13	5.491e-22	7.019e-02
11	.35	4.000e+13	3.351e-22	5.527e-02
12	.25	7.700e+13	2.591e-22	8.226e-02
13	.15	2.000e+14	9.119e-23	7.520e-02
14				
15				
16				
17				
18				
19				
20				

TOTALS: 3.834e+14 4.130e-01

MicroSkyshine

=====
 (Nuclear & Radiological Safety Analysis - 1.16-007)
 Page: 1 File Ref: _____
 File: CASE7100.SKY Date: ___/___/___
 Run: 1:43 p.m. By: _____
 : September 12, 1996 Checked: _____

CASE: Vertical Cylinder - Skyshine @ 100 m

GEOMETRY: Vertical cylinder area source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	100.
Depth of source behind wall.....	Y	0.16
Offset of detector.....	Z	0.
Depth of dose point.....	H	-0.1
Distance between center of source and wall...	R1	0.01
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	3.575
Height of source.....	L	1.6952

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Vertical Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
-----	-----	-----	-----
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

CASE: Vertical Cylinder - Skyshine @ 100 m

SOURCE NUCLIDES:

Nuclide	Curies	Nuclide	Curies
Ba-137m	3.3491e+04	Cs-137	3.5043e+04
Eu-154	2.5773e+03		

RESULTS:

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	1.30	3.819e+13	2.345e-22	3.692e-02
2	1.01	2.757e+13	1.851e-22	2.104e-02
3	.84	1.751e+13	1.444e-22	1.043e-02
4	.66	1.143e+15	1.167e-22	5.499e-01
5	.48	9.308e+11	8.087e-23	3.104e-04
6	.40	1.997e+11	5.948e-23	4.898e-05
7	.24	6.296e+12	2.663e-23	6.913e-04
8	.20	2.166e+11	1.707e-23	1.525e-05
9	.12	3.859e+13	2.810e-24	4.471e-04
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
TOTALS:		1.272e+15		6.198e-01

MicroSkyshine

(Nuclear & Radiological Safety Analysis - 1.16-007)

Page: 1
 File: CS7100BR.SKY
 Run: 10:12 a.m.
 : May 25, 1996

File Ref: _____
 Date: ___/___/___
 By: _____
 Checked: _____

CASE: Vertical Cylinder - Skyshine @ 100 m - Bremsstrahlung

GEOMETRY: Vertical cylinder area source behind a wall

DIMENSIONS (meters):

Distance between wall and detector.....	X	100.
Depth of source behind wall.....	Y	0.16
Offset of detector.....	Z	0.
Depth of dose point.....	H	-0.1
Distance between center of source and wall...	R1	0.01
Thickness of cover slab.....	T1	0.
Thickness of second shield.....	T2	0.1524
Radius of source.....	W	3.575
Height of source.....	L	1.6952

INTEGRATION PARAMETERS:

Number of Radial Segments.....	M	5
Number of Circumferential Segments.....	N	5
Number of Vertical Segments.....	C	5
Quadrature Order.....		16

MATERIAL DENSITIES (g/cc):

Ambient air: .0012

Material	Cover Slab	Lower Shield	Volume Source
-----	-----	-----	-----
Air			
Water			0.56
Concrete		1.6	1.6
Iron			
Lead			
Zirconium			
Urania			

Buildup factor based on: AIR.

CASE: Vertical Cylinder - Skyshine @ 100 m - Bremsstrahlung

SOURCE NUCLIDES:

Source was entered by energy groups.

RESULTS:

Group #	Energy (mev)	Activity (photons/sec)	Dose point rads/photon	Dose rate (mr/hr)
1	2.30	3.400e+07	3.346e-22	4.691e-08
2	2.10	6.300e+09	3.240e-22	8.418e-06
3	1.90	6.000e+10	3.016e-22	7.463e-05
4	1.70	2.400e+11	2.694e-22	2.666e-04
5	1.48	9.800e+11	2.312e-22	9.345e-04
6	1.23	2.800e+12	2.276e-22	2.628e-03
7	1.00	5.100e+12	1.838e-22	3.865e-03
8	.82	7.200e+12	1.398e-22	4.150e-03
9	.65	1.900e+13	1.149e-22	9.001e-03
10	.47	3.100e+13	7.945e-23	1.016e-02
11	.35	4.000e+13	4.727e-23	7.796e-03
12	.25	7.700e+13	2.818e-23	8.948e-03
13	.15	2.000e+14	8.415e-24	6.940e-03
14				
15				
16				
17				
18				
19				
20				
TOTALS:		3.834e+14		5.477e-02

APPENDIX D
INFORMATION VALIDATION FORMS

This page intentionally left blank.

Information Validation Form

Tracking # IVF-Chapter 3-05

Name of Originator Grant W. Ryan (376-5114)	Organization or Team Chapter 3- Accident Analysis- Subsurface Leak/Subsurface Plume	Date April 25, 1996
<p>Statement of Problem</p> <p>The depth of transfer piping is an important factor in the analysis of a subsurface leak and subsequent subsurface plume. In this scenario is it assumed that a pool does not develop on the surface.</p> <p>Drawing H-2-71912, <i>Structural Central Pump Pits 241-AN-01A Thru -07A</i>, shows the centerline of a transfer pipe to be approximately 1.1 m (3.7 ft) below the soil surface. For simplicity it is recommended, and will be assumed, that the subject accident scenario consider a transfer line at a depth of 1.0 m (3.3 ft).</p> <p>EXPLICITLY concur with or deny (by including appropriate documentation) the assumption made above.</p> <p>REFERENCE</p> <p>Drawing H-2-71912, <i>Structural Central Pump Pits 241-AN-01A Thru -07A</i></p>		
Alternatives 5 N/A	Consequences to Alternatives 6 N/A	
Decision Reached 7	Basis for Decision 8	
Date Requested 9 April 25, 1996	Sent To 10 J. Blackwell, G. Hanson L. Ruffin, C. Carro, Project Files	Date Requested By 11 May 2, 1996 (earlier response would be appreciated)
Response #1 Agree with the assumption made above. I would reference drawing H-2-7991 instead, although it's not critical. I would also like to mention that it is possible that a transfer line in AW farm is only buried approx. 2 ft. below the soil surface. I have not been able to confirm this as of yet. In any event, if this is the only line buried 2 ft., I would hope that you will use the 3.3 ft. as a bounding case anyway. 12		
Response #2 13		
Attachments (List) 14	References (List) 15	

Responder #1 Name and Signature	Responder #2 Name and Signature	
16 Lankford Ruffin <i>L.R.</i> 5/1/96	17	
POC:	Filed:	Routed:
Further Action Required (i.e., RML, Senior Management Attention, etc.)		
18		

Information Validation Form

Tracking # IVF-Chapter 3-06

Name of Originator 1	Organization or Team 2	Date 3
Grant W. Ryan (376-5114)	Chapter 3- Accident Analysis- Subsurface Leak/Subsurface Plume	June 6, 1996

Statement of Problem

The analysis of the *Subsurface Leak and Resulting Subsurface Plume That Does Not Create a Surface Pool* considers the following assumptions:

1. The subsurface leak/subsurface plume does not create a surface pool.
2. The leak volume created is based on a leak of 5% of a 100 gal/min flow rate for a time period of 24 hours. Calculating produces:

$$(100 \text{ gal/min})(60 \text{ min/hr})(24 \text{ hr})(0.05) = 7,200 \text{ gal (27,250 L) over 24 hours.}$$

This is equivalent to $(7,200 \text{ gal}) / (7.48 \text{ gal/ft}^3) = 962.57 \text{ ft}^3$ of waste leaked. The metric equivalent volume is 27.25 m^3 .

Higher leak rates/volumes are likely to create a surface pool which is separately analyzed.

3. The source term used in this scenario is made up of 67 vol% SST Liquids and 33 vol% SST Solids (Cowley 1996). The assumed density of this aqueous mixture is 1.4 g/cm^3 (87.5 lb/ft^3). This is a reasonably conservative source term for this accident scenario since only SST Liquids and Solids are transferred through single-walled buried transfer pipes.

4. The waste leak is assumed to contaminate the soil up to 15.24 cm (6 in) below the soil surface.

15.24 cm (6 in) of soil cover maximizes radiation dose consequences in this accident scenario since lesser soil cover may aid in the leak migrating to the surface and creating a pool, which is analyzed separately.

Greater thicknesses of soil cover provide more shielding from the source and therefore reduce the direct, skyshine, and bremsstrahlung radiation dose consequences.

5. The density of the soil is assumed to be 1.6 g/cm^3 . This value is consistent with calculations and models used in WHC-SD-WM-SARR-016, Rev. 2.

Higher density soils can be found on the Hanford Site, however, the density assumed here is considered representative and will provide conservative radiological consequence results.

6. The soil porosity (void fraction) is assumed to be 0.40. These pores/voids are where the leaked waste resides.

A soil with a lower porosity (i.e., 0.30) was also investigated in the analysis of this accident scenario. It was found that developing the consequences with a lower void fraction would not result in conservative dose consequences since the volume of contaminated soil would be larger and therefore provide more self-shielding.

EXPLICITLY concur with or deny (by including appropriate documentation) the assumption made above.

REFERENCES

Cowley, W. L., 1996, *Development of Radiological Concentrations and Unit Liter Doses for TWRS FSAR Radiological Consequence Calculations*, WHC-SD-WM-SARR-037, Rev. 0, Westinghouse Hanford Company, Richland, Washington.

REFERENCES (Continued) Savino, A. V., 1996, WHC-SD-WM-SARR-016, Rev. 2, <i>Tank Waste Compositions and Atmospheric Dispersion Coefficients for use in ASA Consequence Assessments</i> , Westinghouse Hanford Company, Richland, Washington.		
Alternatives 5 N/A		Consequences to Alternatives 6 N/A
Decision Reached 7		Basis for Decision 8
Date Requested 9 June 6, 1996	Sent To 10 G. Hanson, L. Ruffin, C. Carro, R. Tucker, Project Files	Date Requested By 11 June 14, 1996 (earlier response would be appreciated)
Response #1 12 <i>Agree with Assumptions W/A 6/6/96 GN HANSON</i>		
Response #2 13		
Attachments (List) 14		References (List) 15
Responder #1 Name and Signature 16 <i>GN HANSON W/A</i>		Responder #2 Name and Signature 17
POC: Filed:		Routed:
Further Action Required (i.e., RML, Senior Management Attention, etc.) 18		

This page intentionally left blank.

2.0 PEER REVIEW CHECKLIST

(A HEDOP review checklist is not required since inhalation dose calculations are not performed.)

This page intentionally left blank.

CHECKLIST FOR PEER REVIEW

Document Reviewed: "Calculation Notes That Support Accident Scenario and Consequence Development for Subsurface Leak Remaining Subsurface Accident," WHC-SD-WM-CN-004, Rev. 1, 9/96, by Grant Ryan.

Scope of Review: Entire Document.

Yes	No	NA	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Previous reviews complete and cover analysis, up to scope of this review, with no gaps.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Problem completely defined.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Accident scenarios developed in a clear and logical manner.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Necessary assumptions explicitly stated and supported.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer codes and data files documented.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data used in calculations explicitly stated in document.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data checked for consistency with original source information as applicable.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Mathematical derivations checked including dimensional consistency of results.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Models appropriate and used within range of validity or use outside range of established validity justified.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Hand calculations checked for errors. Spreadsheet results should be treated exactly the same as hand calculations.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Software input correct and consistent with document reviewed.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Software output consistent with input and with results reported in document reviewed.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Limits/criteria/guidelines applied to analysis results are appropriate and referenced. Limits/criteria/guidelines checked against references.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Safety margins consistent with good engineering practices.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Conclusions consistent with analytical results and applicable limits.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Results and conclusions address all points required in the problem statement.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Format consistent with appropriate NRC Regulatory Guide or other standards
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Review calculations, comments, and/or notes are attached.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Document approved.

Anthony V. Savino *Anthony V. Savino*
 Reviewer (Printed Name and Signature)

9/18/96
 Date

This page intentionally left blank.